## POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER, LDC, DHAKA. DAILY REPORT

Oil Consumed (PDB):

QF-LDC-08 Page -1

Reporting Date : Till now the maximum generation is: - MW at 4296 N 20:00 Hrs The Summary of Yesterday's ( ) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation Hour 12:00 Min Gen. at 3057 MW **Evening Peak Generation** 3852 3 1/1/1/ Hour 20:00 Max Generation 3630 MW E.P. Demand (at gen end) 4400.0 MW Hour 20:00 Max Demand 4500 MW Maximum Generation 3856.3 MW 870 MW Hour 23:00 Shortage Total Gen. (MKWH) 92.35% 739 MW 78.71 System L/ Factor Load Shed

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 390 MW

Water Level of Kaptai Lake at 6:00 A M of 15-Nov-09

Actual: 101.76 Ft.(MSL), Rule curve: 107.60 Ft.(MSL)

MMCFt

HSD : 275991 Liter

FO: 0 Liter

Cost of the Consumed Fuel (PDB): Gas : Tk50,628,350 Oil : Tk11,039,622 Total : Tk61,667,972

## **Load Shedding & Other Information**

685.00

Gas Consumed: Total

Area	Yesterday Actual Shedding (s/s end)		Today			
ľ			Estimated Demand(s/s end)	Estimated Shedding (s/s end	Rates of Shedding	
	MW	fro to	MW	MW	(On Estimated Demand)	
Dhaka	138 (	(18:05-00:15, gen. shortage)	1730	335	19%	
Chittagong Area	72	(18:05-00:15, gen. shortage)	447	94	21%	
Khulna Area	70 (	(18:05-23:48, gen. shortage)	382	81	21%	
Rajshahi Area	36 (	(18:05-00:02, gen. shortage)	304	64	21%	
Comilla Area	59 (	(18:05-23:46, gen. shortage)	312	68	22%	
Mymensing Area	46 (	(18:05-23:46, gen. shortage)	212	45	21%	
Sylhet Area	-		188	-	-	
Barisal Area	11 (	(18:05-23:48, gen. shortage)	79	16	20%	
Rangpur Area	33 (	(18:05-00:02, gen. shortage)	170	36	21%	
Tatal	405	20.00	2004	700		
Total	465	20:00	3824	739		

## Information of the Generating machines under maintenance

Planned Shut- Dowr		Forced Shut- Down	
1) Khulna 60 MW (05/07/06)	1) Kaptai- 3 (19/04/08)	9) Shahjibazar -6 (11/10/09).	
	2) Shajibazar- 2 (13/07/08)	10) Raozan -1 (19/10/09)	
	3) Shajibazar-4 (18/10/08)	11) Raozan -2 (08/11/09)	
	4) Khulna 110 (31/03/09)	12) Fenchuganj ccpp steam (12/11/09)	
	5) RPCL GT-4 (06/06/09)	13) Ashuganj -3 (13/11/09)	
	6) Haripur SBU GT-3 (18/06/09).		
	7) Baghabari GT-2 (02/07/09)		
	8) Shahjibazar 5 (05/08/09)		

## Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 465 MW (20:00) of load shed was imposed over the whole

- b) Due to gas limitation Tongi GT (105 MW), NEPC (85 MW), HPL (360 MW) and RPCL (160 MW)
- were limited to 35 MW, 30 MW, 301 MW and 120 MW respectively.
  c) Due to gas limitation, Sikalbaha St, Haripur SBU GT-2 (32 MW), Raozan -1, 2, and Shahjibazar-4 & 5 were under shut down.
- d) Ghorasal -2 was forced shut down at 12:20 due to CW pump problem .
- e) After maintenance, WMPL GT-1 was synchronized at 17:06.
- f) Fenchuganj CCPP GT-1 was forced shut down at 00:55 (15/11/09) due to cooling water line leakage. It may be synchronized before evening peak hour today.
- g) MPL GT-1, GT-2 and Steam were shut down at 05:40 (15/11/09), 05:42 (15/11/09) and 05:51 (15/11/09) respectively due to schedule maintenance.
- h) Hasnabad 132/33 KV T2 transformer, Kalyanpur 132/33 KV T1 transformer, Kabirpur Tangail 132 KV line -2, Sikalbaha Dohazari 132 KV line -1, Aminbazar 230/132 KV T3 transformer, Haripur Shyampur 132 KV line, Shyampur 132/33 KV T3 transformer, C. Nababganj 132/33 KV T2 transformer and Kishorganj 132/33 KV T2 transformer line -2 were under annual maintenance from 08:25 to 14:55, 08:25 to 11:26, 08:10 to 17:45, 09:38 to 16:32, 09:40 to 17:55, 09:42 to 17:57, 09:44 to 18:10, 09:15 to 15:50, 10:05 to 14:12 respectively.
- i) Kamrangirchar Kalyanpur 132 KV line was under shut down from 08:10 to 16:40 due to maintenance of line isolator at Kamrangirchar end.
- j) Feni Hathazari 132 KV line -1 was under shut down from 08:40 to 16:30 due to changing of cross arm of Tower no. - 586.
- k) Madanhat Sikalbaha 132 KV line -1 and Ashuganj Ghorasal 230 KV line -2 were under NLDC project work from 10:01 to 13:51 and 09:47 to 18:25 respectively.
- I) Netrokona 132/33 KV T2 transformer is under annual maintenance since 07:30 (15/11/09).
- m) Jamalpur 132/33 KV T3 transformer tripped at 07:40 (15/11/09) showing ' Differential lockout It is now under inspection and maintenance.
- n) Tangail Kabirpur 132 KV line -2 , Basundhara Tongi 132 KV line -1 & 2, Kaptai Chandraghona 132 KV line -2 and Kaptai Madanhat 132 KV line -1 are under annual maintenance since 08:12 (15/11/09), 08:35 (15/11/09), 08:36 (15/11/09), 09:10 (15/11/09) and 09:19 (15/11/09) respectively.

So about 465 MW (20:00) of load shed was imposed over the whole area (except Sylhet) of the national grid .

Load Despatch Division Load Despatch Division Load Despatch Circle