

## CENTRAL LOAD DESPATCH CENTRE

## DAILY REPORT

MIS=302  
Page -1

Till now the maximum generation is :-		3782.1 MW	at	20:00	on	30-Oct-05	Reporting Date : 16-Mar-07
<b>The Summary of Yesterday's (</b>		15-Mar-07	<b>) Generation &amp; Demand</b>		<b>Today's Actual Min Gen. &amp; Probable Gen. &amp; Demand</b>		
Day Peak Generation :	2973.0	MW	Hour :	10:00	Min Gen. at	5:00	2628.5 MW
Evening Peak Generation :	3060.3	MW	Hour :	20:00	Max Generation :		3373 MW
E.P. Demand (at gen end) :	3900.0	MW	Hour :	20:00	Max Demand :		3700 MW
Maximum Generation :	3076.3	MW	Hour :	22:00	Shortage		327 MW
Total Gen. (MKWH) :	66.88	System L/ Factor :		90.58%	Load Shed		288 MW
<b>EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR</b>							
Export from Ghorasal to Ishurdi :- Maximum		348 MW	at	5:00	Energy	6666000 KWHR.	
Import from Ishurdi to Ghorasal:- Maximum		-	MW	at	-	Energy	- KWHR.
Water Level of Kaptai Lake at 6:00 A M of 16-Mar-07							
Actual :	77.33	Ft.(MSL)	Rule curve :	90.60	Ft.( MSL )		
Gas Consumed :	PDB	398.67	MMCFt.	Oil Consumed :			
	WMPL	22.21	MMCFt.	PDB	SKO :	38649	Liter
	RPCL	25.58	MMCFt.		HSD :	364321	Liter
	NEPC	15.47	MMCFt.		FO :	0	Liter
	CDC (H+M)	119.67	MMCFt.				
	Total	581.60	MMCFt.				
Cost of the Consumed Fuel (PDB) : Gas :			Tk29,465,699	Oil :	Tk10,205,740	Total :	Tk39,671,438

## Load Shedding &amp; Other Information

Area	Yesterday				Today			
	Actual Shedding (s/s end), MW				Estimated Demand(s/s end) MW	Estimated Shedding (s/s end) MW	Rates of Shedding (On Estimated Demand)	
	from	18:00	to	till now				
DESA		120			1390	79	6%	
Chittagong Area		124			418	47	11%	
Khulna Area		138			356	40	11%	
Rajshahi Area		122			344	39	11%	
Comilla Area		76			238	27	11%	
Mymensing Area		48			154	17	11%	
Sylhet Area		34			145	16	11%	
Barisal Area		28			75	8	11%	
Rangpur Area		51			136	15	11%	
Total		741	(	20:00)	3256	288		

## Information of the Generating machines under maintenance

Planned Shut-Down	Forced Shut-Down
1) Sahjibazar GT-5 (09/03/05)	1) Haripur SBU GT -1 (19/05/05)
2) Sahjibazar GT-6 (16/11/04)	2) Haripur SBU GT-3 (25/05/05)
3) Ashuganj -5 (25/12/05),	3) Haripur SBU GT-2 (06/03/06).
	4) Sikalbaha BMPP-1 (15/12/01)
	5) Ghorasal -1 (30/11/06)
	6) Sahjibazar GT-8 (29/07/06)
	7) Sahjibazar GT-9 (09/02/06)
	8) Khulna 60 MW (05/07/06)
	9) Bheramara GT-2 -(29/07/06 )
	10) Kaptai -5 (30/07/06)
	11) Shahjibazar GT4 -05/10/06
	12) Sikalbaha Steam (27/11/06)
	13) Baghabari-71MW (26/02/2006)
	14) Barapukuria -2 (15/03/07)
	15) Ashuganj CCPP St-02/03/07
	16) Khulna 110 MW (09/03/07)
	17) Ashuganj -1 (13/03/07)
	19) Ghorasal -3 (02/03/07)

## Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 741 MW (20:00) of load shed was imposed over the whole area of National grid .
b) Baghabari GT-2 (100 MW ) tripped at 08:18 due to reverse power and was synchronized at 15:05.	
c) Barapukuria unit -2 was shut down at 17:03 due to boiler recirculation valve problem. It is now under maintenance.	
d) Baghabari WMPL unit -2 was forced shut down at 00:08 (16/03/07) due to compressor water wash and filter change. It may be synchronized before evening peak hour today.	
e) Sylhet GT (20 MW) was shut down at 00:22 ( 16/03/07) due to combustion chamber inspection. It may be synchronized before evening peak hour today.	
f) After maintenance, Raozan unit -1 was synchronized at 02:12 (16/03/07)	
g) Haripur - Maniknagar 132 KV pole line tripped from Maniknagar S/S end showing 'DIST relay' and was switched on at 10:24.	
h) After installation of optical fiber, Bottail - Bheramara 132 KV line -1 was switched on at 14:56.	Due to low voltage, about 30MW of load shed has been running since morning (16/03/07) over Khulna and Barisal areas.

Deputy Manager  
Load Despatch DivisionManager  
Load Despatch DivisionDeputy General Manager  
Load Despatch Circle