

Till now the maximum generation is : -	MW at	3782.1	20:00	Reporting Date : 13-May-07
				30-Oct-05
<b>The Summary of Yesterday's (</b>		<b>) Generation &amp; Demand</b>		<b>Today's Actual Min Gen. &amp; Probable Gen. &amp; Demand</b>
Day Peak Generation :	12-May-07	MW	Ho 12:00	Min Gen. at 7:00 2669 MW
Evening Peak Generation :		MW	Ho 20:00	Max Generation : 3579 MW
E.P. Demand (at gen end) :		MW	Ho 20:00	Max Demand : 4500 MW
Maximum Generation :		MW	Ho 22:00	Shortage : 921 MW
Total Gen. (MKWH) :		69.15	System L/ Factor 82.29%	Load Shed : 810 MW

**EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR**

Export from Ghorasal to Ishurdi :- Maximum	330 MW	at 1:00	Energy	4735500 KWHR.
Import from Ishurdi to Ghorasal:- Maximum	- MW	at -	Energy	- KWHR.

**Water Level of Kaptai Lake at 6:0 13-May-07**

Actual :	72.97	Ft.(MSL) ,	Rule curve :	79.72	Ft.( MSL )
Gas Consumer: PDB	451.70	MMCFt.	Oil Consumed :		
WMPL	6.88	MMCFt.	PDB	SKO :	34242 Liter
RPCL	37.10	MMCFt.		HSD :	249055 Liter
NEPC	11.61	MMCFt.		FO :	0 Liter
CDC (H+M)	112.51	MMCFt.			
Total	619.80	MMCFt.			
Cost of the Consumed Fuel (PDB) : Gas :		Tk33,385,317	Oil :	Tk7,176,076	Total : Tk40,561,393

**Load Shedding & Other Information**

Area	Yesterday		Today		Rates of Shedding (On Estimated Demand)
	Actual Shedding (s/s end), MW		Estimated Demand(s/s end)	Estimated Shedding (s/s end)	
from	to	18:30 till now	MW	MW	
DESA		195	1641	300	18%
Chittagong Area		100	515	113	22%
Khulna Area		120	431	95	22%
Rajshahi Area		115	404	89	22%
Comilla Area		70	308	68	22%
Mymensing Area		30	216	47	22%
Sylhet Area		25	172	38	22%
Barisal Area		25	84	18	21%
Rangpur Area		45	189	42	22%
Total		725 20:00	3960	810	

**Information of the Generating machines under maintenance**

Planned Shut- Down	Forced Shut- Down
1) Sahjibazar GT-5( 09/03/05)	1) Haripur SBU GT -1 (19/05/05)
2) Sahjibazar GT-6(16/11/04)	2) Haripur SBU GT-3 (25/05/05)
3) Ashuganj -5 (25/12/05),	3) Haripur SBU GT-2 (06/03/06).
	4) Sikalbaha BMPP-1(15/12/01)
	5) Ghorasal -1 (23/03/07)
	6) Sahjibazar GT-8(29/07/06)
	7) Sahjibazar GT-9(09/02/06)
	8) Khulna 60 MW (05/07/06)
	9) Bheramara GT-3 -(27/02/07)
	10) Kaptai -5 (30/07/06)
	11) Sikalbaha Steam (27/11/06)
	12) Baghabari-71MW(26/02/2006)
	13) Barisal GT-2 (20/03/07)
	14) Siddhirganj -50 MW(25/04/07)
	15) Khulna 110 MW (25/04/07)
	16) Westmont-2 (10/05/07)
	17) Ashuagnj st-1 (11/05/07)
	18) Ashuganj CCPP st(12/05/07)

**Additional Information of Machines, lines, Interruption / Forced Load shed etc**

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 725 MW (20:00) of load shed was imposed over the whole areas of the national grid.
b) Baghabari Westmont unit -2 tripped at 19:03 due to voltage fluctuation and was synchronized at 21:35.	
c) Ashuganj CCPP Steam unit was forced shut down at 15:05 due to feed pump leakage. It is now under maintenance.	
d) Ishurdi 230/132 KV T03 transformer was under shut down from 10:59 to 15:30 due to oil leakage from 132 KV R-phase bushing and 230 KV mid breaker no.- 805 B was switched on 13:05.	
e) Sylhet - Chatak 132 KV line -1 was under shut down from 11:12 to 11:25 due to due to Air compressor problem of breaker at Sylhet S/S end.	
f) Chatak 132/33 KV T2 transformer tripped at 11:30 showing ' Over current' due to 33 KV Paper Mill feeder fault and was switched on at 11:37.	
	Due to low voltage , about 150 MW of load shed has been running since morning (13/05/07) over DESA, Khulna & Barisal areas of the National grid.

Deputy Manager  
Load Despatch Division

Manager  
Load Despatch Division

Deputy General Manager  
Load Despatch Circle