

Till now the maximum generation is : -		MW at	3782.1	20:00	Reporting Date : 14-May-07
					30-Oct-05
The Summary of Yesterday's (13-May-07) Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand
Day Peak Generation :	2851.0	MW	Ho	11:00	Min Gen. at 7:00 : 2761 MW
Evening Peak Generation :	3557.1	MW	Ho	20:00	Max Generation : 3340 MW
E.P. Demand (at gen end) :	4500.0	MW	Ho	20:00	Max Demand : 4500 MW
Maximum Generation :	3557.1	MW	Ho	20:00	Shortage : 1160 MW
Total Gen. (MKWH) :	74.28	System L/ Factor	87.01%		Load Shed : 1021 MW
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR					
Export from Ghorasal to Ishurdi :- Maximum		336 MW	at	21:00	Energy 5857500 KWHR.
Import from Ishurdi to Ghorasal:- Maximum		- MW	at	-	Energy - KWHR.
Water Level of Kaptai Lake at 6:0 14-May-07					
Actual :	72.89	Ft.(MSL) ,	Rule curve :	79.53	Ft.(MSL)
Gas Consumer: PDB	480.33	MMCFt.	Oil Consumed :		
WMPL	14.98	MMCFt.	PDB	SKO :	56940 Liter
RPCL	45.34	MMCFt.		HSD :	251428 Liter
NEPC	14.03	MMCFt.		FO :	0 Liter
CDC (H+M)	112.65	MMCFt.			
Total	667.33	MMCFt.			
Cost of the Consumed Fuel (PDB) : Gas :		Tk35,501,184	Oil :	Tk7,814,461	Total : Tk43,315,645

Load Shedding & Other Information

Area from	Yesterday Actual Shedding (s/s end), MW		Today Estimated Demand(s/s end)		Rates of Shedding (On Estimated Demand)
	18:30	till now	MW	MW	
DESA	216		1641	300	18%
Chittagong Area	112		515	160	31%
Khulna Area	188		431	134	31%
Rajshahi Area	55		404	126	31%
Comilla Area	95		308	96	31%
Mymensing Area	43		216	67	31%
Sylhet Area	43		172	53	31%
Barisal Area	30		84	26	31%
Rangpur Area	47		189	59	31%
Total	829	20:00	3960	1021	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Sahjibazar GT-5(09/03/05)	1) Haripur SBU GT -1 (19/05/05)
2) Sahjibazar GT-6(16/11/04)	2) Haripur SBU GT-3 (25/05/05)
3) Ashuganj -5 (25/12/05),	3) Haripur SBU GT-2 (06/03/06).
	4) Sikalbaha BMPP-1(15/12/01)
	5) Ghorasal -1 (23/03/07)
	6) Sahjibazar GT-8(29/07/06)
	7) Sahjibazar GT-9(09/02/06)
	8) Khulna 60 MW (05/07/06)
	9) Bheramara GT-3 -(27/02/07)
	10) Kaptai -5 (30/07/06)
	11) Sikalbaha Steam (27/11/06)
	12) Baghabari-71MW(26/02/2006)
	13) Barisal GT-2 (20/03/07)
	14) Siddhirganj -50 MW(25/04/07)
	15) Khulna 110 MW (25/04/07)
	16) Ashuagnj st-1 (11/05/07)
	17) Raozan unit 2(14/05/07)

Additional Information of Machines, lines, Interruption / Forced Load shed etc

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 829 MW (20:00) of load shed was imposed over the whole areas of the national grid.
b) After maintenance, Baghabari Westmont unit -2 was synchronized at 12:48.	
c) After maintenance, Ashuganj CAPP Steam unit was synchronized at 23:38. But again it was forced shut down at 08:47 (14/05/07) due to feed pump leakage. It is now under maintenance.	
d) Shahjibazar unit 5 was forced shut down at 23:39 due to carbon brush sparking. It may be synchronized before evening peak hour today.	
e) Raozan unit -2 is under shut down since 01:12 (14/05/07) due to economizer and sealing steam leakage. It is now under maintenance.	
f) Bogra - Sherajganj 132 KV line -2 was under shut down from 09:51 to 12:26 due to replacement of CVT at Bogra S/S end.	So about 10 MW of power interruption occurred under Bagerhat S/S areas from 16:52 to 17:12.
g) Bagerhat 132/33 KV T1 and T2 transformers tripped at 16:52 showing 'Lock out and trip trip ckt. Not healthy' and were switched on at 17:12 and 17:15 respectively.	
h) Tongi - Ghorasal 230 KV ckt.-1 is under shut down since 07:43 (14/05/07) due to installation of optical fiber.	Due to low voltage and Mvar problem, about 180 MW of load shed has been running since morning (14/05/07) over DESA, Chittagong, Khulna & Barisal areas of the National grid.

Deputy Manager
Load Despatch Division

Manager
Load Despatch Division

Deputy General Manager
Load Despatch Circle