

Reporting Date : 9-Jun-07

Till now the maximum generation is : -

3782.1 MW

20:00

on

30-Oct-05

9-Jun-07

The Summary of Yesterday's (8-Jun-07) Generation & Demand			Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :	2875.0	MW	Hour :	10:00	Min Gen. at	6:00	2358.2 MW
Evening Peak Generation :	3358.0	MW	Hour :	20:00	Max Generation	:	3460 MW
E.P. Demand (at gen end) :	3700.0	MW	Hour :	20:00	Max Demand	:	4200 MW
Maximum Generation :	3370.6	MW	Hour :	21:00	Shortage	:	740 MW
Total Gen. (MKWH) :	66.83		System L/ Factor :	82.62%	Load Shed	:	651 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from Ghorasal to Ishurdi :- Maximum	300 MW	at 20:00	Energy	5346000 KWHR.
Import from Ishurdi to Ghorasal:- Maximum	-	at -	Energy	- KWHR.

Water Level of Kaptai Lake at 6:00 A M of

9-Jun-07

Actual : 69.07 Ft.(MSL) , Rule curve : 78.08 Ft.(MSL)

Gas Consumed :	PDB	403.45	MMCFt.	Oil Consumed :			
	WMPL	20.46	MMCFt.	PDB	SKO :	56082	Liter
	RPCL	30.39	MMCFt.		HSD :	293922	Liter
	NEPC	13.01	MMCFt.		FO :	0	Liter
	CDC (H+M)	118.59	MMCFt.				
	Total	585.89	MMCFt.				

Cost of the Consumed Fuel (PDB): Gas :		Tk29,818,905	Oil :	Tk8,868,125	Total :	Tk38,687,029
----------------------------------------	--	--------------	-------	-------------	---------	--------------

Load Shedding & Other Information

Area	Yesterday		Today			
	Actual Shedding (s/s end), MW		Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)	
	from 18:30	to till now				
DESA	45		1531	203	13%	
Chittagong Area	-		480	99	21%	
Khulna Area	145		405	84	21%	
Rajshahi Area	-		379	79	21%	
Comilla Area	50		286	59	21%	
Mymensing Area	-		202	42	21%	
Sylhet Area	35		158	33	21%	
Barisal Area	27		79	16	20%	
Rangpur Area	-		176	36	20%	
Total	302	(20:00)	3696	651		

Information of the Generating machines under maintenance

Planned Shut-Down	Forced Shut-Down
1) Ashuganj -5 (25/12/05),	8) Bheramara GT-3 -(27/02/07)
2) Haripur SBU GT -1 (19/05/05)	9) Kaptai -5 (30/07/06)
2) Haripur SBU GT-3 (25/05/05)	10) Sikalbaha Steam (06/06/07)
3) Sikalbaha BMPP-1(15/12/01)	11) Baghabari-71 MW(26/02/2006)
4) Ghorasal -1 (23/03/07)	12) Khulna 110 MW (25/04/07)
5) Sahjibazar GT-8(29/07/06)	13) RPCL steam (04/06/07)
6) Sahjibazar GT-9(09/02/06)	14) Ghorasal 4 (05/06/07)
7) Khulna 60 MW (05/07/06)	

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description		Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .		So about 302 MW (20:00) of load shed was imposed over the whole area of the national grid.
b) After maintenance, Ashuganj unit- 3 was synchronized at 18:42		
c) After maintenance, Ghorasal unit- 2 was synchronized at 01:45 (09/06/07).		
d) Tongi - Basundhora 132 KV line -1 was under shut down from 08:35 to 13:50 for attending red hot maintenance at Tongi S/S end.		
e) Ishurdi - Baghabari - Pubna - Shahajadpur 132 KV line was under shut down from 08:22 to 14:50 for project work.		
f) Shajadpur 132/33 KV T4 transformer was under shut down from 11:18 to 17:06 for attending red hot maintenance		
g) Haripur 230/132 KV (new) TR3 transformer was switched on at 16:42 (no load).		
h) Khulna central - Khulna (south) 132 KV ckt is under shut down since 05:30 (09/06/07) for project work.		So about 8 MW of partial power interruption has been occurring under Satkhira S/S areas since 05:30 (09/06/07)
		Due to low Voltage, about 60 MW of load shed has been running since morning (09/06/07) over Khulna and Barisal area of the national grid.

Deputy Manager
Load Despatch Division

Manager
Load Despatch Division

Deputy General Manager
Load Despatch Circle