DAILY REPORT

					Reporting Date :	17-Jun-07
Till now the maximum generation is	s:-	3782.1 MW at	20:00	on	30-Oct-05	
The Summary of Yesterday's (16-Jun-07) Generation & Demand		Today's Actual M	in Gen. & Probable Ge	en. & Demand
Day Peak Generation :	2838.0	MW Hour :	10:00	Min Gen. at	6:00	2296.6 MW
Evening Peak Generation :	3296.5	MW Hour :	20:00	Max Generation	:	3426 MW
E.P. Demand (at gen end):	4100.0	MW Hour :	20:00	Max Demand	:	4100 MW
Maximum Generation :	3296.5	MW Hour :	20:00	Shortage	:	675 MW
Total Gen. (MKWH) :	65.92	System L/ Factor :	83.32%	Load Shed	:	594 MW
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR						
Export from Ghorasal to Ishurdi :- Ma		330 MW at	1:00	Energy	6616500 KWHR.	

Import from Ishurdi to Ghorasal:- Ma	-	MV	/ at	-		Energy	-	KWHR.	
V	Vater Level of Kap	tai Lake at 6:00	A M of 17-	Jun-07					
Actual : 81.46	Ft.(MSL),		Rule curve :	80.22	Ft.(MSL)				
Gas Consumed : : PDB	397.06	MMCFt.	Oil	Consumed	:				
WMPL	19.97	MMCFt.		PDB		SKO	:	38649	Liter
RPCL	58.80	MMCFt.				HSD	:	230545	Liter
NEPC	13.25	MMCFt.				FO	:	0	Liter
CDC (H+M)	114.13	MMCFt.							
Total	603.20	MMCFt.							
Cost of the Consumed Fuel (PDB):	Gas :		Tk29,346,759	Oil :	Tk6,819,86	60	Total:	Tk36,166,6	18

Load Shedding & Other Information

Area	Yesterday			Today			
	Actual Shedding (s/s end), MW		(s/s end), MW	Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding	
	from 18:30	to	till now	MW	MW	(On Estimated Demand)	
Dhaka	204			1496	172	11%	
Chittagong Area	74			466	93	20%	
Khulna Area	140			396	79	20%	
Rajshahi Area	106			369	75	20%	
Comilla Area	72			282	56	20%	
Mymensing Area	19			198	39	20%	
Sylhet Area	27			154	31	20%	
Barisal Area	18			75	15	20%	
Rangpur Area	48			172	34	20%	
Total	708	(20:00) 3608	594		

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down		
1) Ashuganj -5 (25/12/05),	1) Haripur SBU GT -1 (19/05/05)	8) Bheramara GT-3 -(27/02/07)	
	2) Haripur SBU GT-3 (25/05/05)	9) Kaptai -5 (30/07/06)	
	3) Sikalbaha BMPP-1(15/12/01)	10) Barpukuria -2 (09/06/07)	
	4) Ghorasal -1 (23/03/07)	11) Baghabari-71MW(26/02/2006)	
	5) Sahjibazar GT-8(29/07/06	12) Khulna 110 MW (25/04/07)	
	6) Sahjibazar GT-9(09/02/06)	13) Ghorasal -3 (15/06/07)	
	7) Khulna 60 MW (05/07/06)	14) Bheramara GT-2 (16/06/07)	

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 708 MW (20:00) of load shed was imposed over the whole
	area of the national grid.

- b) Fenchuganj GT- 2 was shut down at 00:16 (17/06/07) due to boiler maintenance. It may be synchronized before evening peak hour today.
- c) After maintenance, Siddhirganj 210 MW was synchronized at 00:50 (17/06/07).
 d) Kaptai unit -1, 2 & 4 are under shut down since 06:25 (17/06/07), 06:30 and 05:44 respectively. It may be synchronized before evening peak hour today.
- e) Naogaon 132/33 KV T3 transformer tripped at 10:57 Showing 'PRD' and was switched on at 15:56
- f) Dohazari Cox'Bazar 132 KV line -1 tripped at 13:28 showing ' DIST trip' and was switched on at 13:40.But again it tripped at 14:54 due to the same reason.lt is now under maintenance.
- g) Kabirpur Tangail 132 KV line -2 tripped at 16:55 from Kabirpur S/S end showing 'DIST. trip' and was switched on at 17:22.
- h) Comilla (N) Comilla (S) 132 KV line tripped at 21:15 from Comilla (N) end showing 'DIST trip' . At that time Comilla (S) areas was fully interrupted. Power supply was normalized by switched on 132 KV Comilla (S) Chandpur line at 21:18. Comilla (N) Comilla (S) line switched on at 21:32 and Comilla (S) Chandpur line was switched off at 21:32.

So about 30 MW of power interruption occurred under Tangail S/S areas for 27 minutes.

So about 45 MW of power interruption occurred under Comilla (S) S/S areas for 3 minutes.

Due to low voltage, about 100 MW of load shed has been running since morning (17/06/07) over Khulna and Barisal area of national grid.

 Deputy Manager
 Manager
 Deputy General Manager

 Load Despatch Division
 Load Despatch Division
 Load Despatch Circle