

DAILY REPORT

Reporting Date : 25-Jun-07

Till now the maximum generation is : -

3782.1 MW at 20:00 on 30-Oct-05

The Summary of Yesterday's (24-Jun-07)		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :	3224.0	MW	Hour : 12:00	Min Gen. at 7:00	2872.3 MW
Evening Peak Generation :	3391.8	MW	Hour : 20:00	Max Generation :	3424 MW
E.P. Demand (at gen end) :	4400.0	MW	Hour : 20:00	Max Demand :	4400 MW
Maximum Generation :	3398.8	MW	Hour : 21:00	Shortage :	976 MW
Total Gen. (MKWH) :	74.21	System L/ Factor :	90.98%	Load Shed :	818 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from Ghorasal to Ishurdi :- Maximum	366 MW	at 1:00	Energy	8481000 KWHR.
Import from Ishurdi to Ghorasal:- Maximum	-	MW at -	Energy	- KWHR.

Water Level of Kaptai Lake at 6:00 A M of 25-Jun-07

Actual : 90.68	Ft.(MSL) ,	Rule curve : 82.38	Ft.(MSL)		
Gas Consumed : : PDB	483.54	MMCFt.	Oil Consumed : PDB	SKO :	56784 Liter
WMPL	20.83	MMCFt.		HSD :	205941 Liter
RPCL	27.95	MMCFt.		FO :	0 Liter
NEPC	15.09	MMCFt.			
CDC (H+M)	118.45	MMCFt.			
Total	665.86	MMCFt.			
Cost of the Consumed Fuel (PDB) : Gas :	Tk35,738,415		Oil :	Tk6,659,220	Total : Tk42,397,636

Load Shedding & Other Information

Area	Yesterday				Today			
	Actual Shedding (s/s end), MW				Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)	
	from	18:45	to	till now				
Dhaka		145			1530	193	13%	
Chittagong Area		100			480	139	29%	
Khulna Area		157			400	116	29%	
Rajshahi Area		132			380	109	29%	
Comilla Area		91			290	84	29%	
Mymensing Area		60			220	64	29%	
Sylhet Area		41			155	45	29%	
Barisal Area		37			75	22	29%	
Rangpur Area		79			158	46	29%	
Total		841	(20:00)	3688	818		

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Ashuganj -5 (25/12/05),	9) Kaptai -5 (30/07/06)
	10) Barpukuria -2 (09/06/07)
	11) Baghabari-71MW(26/02/2006)
	12) Khulna 110 MW (25/04/07)
	13) Barisal GT-1 (27/05/07)
	14) Bheramara GT-2 (15/06/07)
	15) RPCL Steam (23/06/07)
	16) Raozan-1 (23/06/07)
	17) Fenchuganj GT-1 (24/06/07)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 841 MW (20:00) of load shed was imposed over the whole area of the national grid.
b) Fenchuganj GT-1 was forced shut down at 17:28 due to remote control pannel problem. It is now under maintenance.	
c) Aminbazar 230 KV bus - II was under shut down from 09:46 to 17:18 due to installation of 3rd bank of power transformer. Power supply was normalized at that time by bus-I.	
d) Tongi 132 KV breaker no.- 612 B was under shut down from 12:39 to 14:15 due to oil filling.	
e) After connection of tower Jumper, Haripur - Comilla 132 KV line -1 & 2 were switched on at 15:25. Again its are under shut down since 07:20 (25/06/07) due to the same reason.	
	Due to low voltage , about 140 MW of load shed has been running since morning (25/06/07) over Khulna and Barisal area of the national grid.

Deputy Manager
Load Despatch Division

Manager
Load Despatch Division

Deputy General Manager
Load Despatch Circle