

QF-LDC-08
Page -1

Reporting Date : 2-Sep-10
Hrs on 20-Aug-10

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Water Level of Kaptai Lake at 6:00 A M of

Actual : 106.17

HSD	:	1803776	Liter
FO	:	0	Liter

Oil : Tk72,151,054

Load Shedding & Other Information

Area	Yesterday		Today		
			Estimated Demand(s/s end) from 10:00 MW	Estimated Shedding (s/s end) from 10:00 MW	Rates of Shedding (On Estimated Demand)
	MW				
Dhaka	371	(18:10-04:20 gen. shortage)	2031	316	16%
Chittagong Area	109	(18:10-04:20 gen. shortage)	576	114	20%
Khulna Area	94	(18:10-04:45 gen. shortage)	525	104	20%
Rajshahi Area	83	(18:10-05:44 gen. shortage)	430	84	20%
Comilla Area	53	(18:10-05:07 gen. shortage)	338	66	20%
Mymensing Area	47	(18:10-05:07 gen. shortage)	225	44	20%
Sylhet Area	19	(18:10-04:15 gen. shortage)	240	22	9%
Barisal Area	11	(18:10-04:45 gen. shortage)	102	20	20%
Rangpur Area	45	(18:10-05:44 gen. shortage)	240	47	20%
Total	832	20:00	4707	817	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
	1) Kaptai- 3 (19/04/08)
	2) Khulna 110MW (31/03/09)
	3) Haripur SBU GT-3 (18/06/09)
	4) Ghorasal 2(26/04/10)
	5) Siddirganj GT-1 (18/06/10)
	6) Ghorasal 6(18/07/10)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 832 MW (20:00) of load shed was imposed over the whole areas of the national grid .
b) Due to gas limitation RPCL (210 MW),Tongi (105 MW) and HPL (360 MW) were limited to 89 MW , 50 MW and 334 MW respectively .	
c) Megnaghat (450 MW) GT-1 & 2 and ST. tripped at 12:59 and 13:38 due to voltage fluctuation and fuel gas compressure trip; and was synchronized at 17:16 & 22:58 and 18:12 respectively.	
d) NEPC tripped at 12:58 showing E/F and was synchronized at 13:56.	
e) Haripur SBU tripped at 12:58 due to under voltage and was synchronized at 14:52.	
f) Siddhirganj PPP tripped at 12:58 due to under voltage and was synchronized at 15:30.	
g) Ashuganj CCPP GT-2 tripped at 12:58 due to exhaust temperature high and was synchronized at 13:50.	
h) Megnaghat ST.was force shut down at 21:01 and was synchronized at 00:52(02/09/10).	
i) Megnaghat GT-2 was force shut down at 21:01 due to leakage of feed water line and was synchronized at 22:58.	
j) Tangail - Haripur 132 KV line -1 shut down at 12:33 due to breaker maintenance at tangail side and was switched on at 12:53.	
k) Siddhirganj -Haripur 132 KV line-2 tripped at 12:58 showing dist. relays by touching mast of river going ship and was switched on at 13:11.	
l) Siddhirganj -Haripur 132 KV line-1 tripped at 13:02 showing dist. Relays and was switched on at 13:23..	
m) Siddhirganj -Haripur 132 KV line-2 was shut down at 07:49(02/09/10) due to maintenance .	
n) Maniknagar 132/33 KV transformer tripped at 07:08(02/09/10) showing O/C relays and was switched on at 07:15.	Power interruption occurred (about 44 MW) under Maniknagar S/S areas from 07:08 to 07:15.
	Due to generation shortage, about 170 MW (09:00) of load shed has been running since morning (02/09/10) over the whole area

Deputy General Manager
Load Despatch Circle