

QF-LDC-08
Page -1

Description		Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.		So about 756 MW (20:00) of load shed was imposed over the whole areas of the national grid.
b) Due to low gas pressure Baghabari 100 MW and RPCL (210 MW) were limited to 60 MW and 107 MW respectively.		
c) After maintenance Mymensingh RPCL ST unit was synchronized at 09:33.		
d) Joydevpur 132/33 kV T-2 was under shut down from 08:44 to 18:40 due to top cover oil leakage.		
e) After maintenance Ashuganj-Kishoreganj line-2 was switched on at 23:35.		
		Due to generation shortage, about 71 MW (09:00) of load shed has been running since morning (04/03/11 over the whole area (except Sylhet) of the national grid.
Deputy / Asstt. Manager Network Operation Division	Manager Network Operation Division	Deputy General Manager Load Despatch Circle