

QF-LDC-08
Page -1

Hrs on 20-Aug-10

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Gas Consumed :	Total	678.34	MMCFt.	Oil Consumed (PDB) :			
					HSD :	890596	Liter
					FO :	494968	Liter

Load Shedding & Other Information

Information of the Generating machines under shut down.

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 724 MW (18:30) of load shed was imposed over the whole areas of the national grid.
b) Due to low gas pressure Baghabari 100 MW and RPCL (210 MW) were limited to 50 MW and 125 MW respectively.	
c) Ashuganj-Shahjibazar 132kV line-3 was under shut down from 09:08 to 14:09 due to corrective maintenance.	
d) Ashuganj-Kishoreganj 132kV line-2 was under shut down from 12:27 to 15:42 due to corrective maintenance.	
e) Khulna 110 MW tripped at 16:10 due to voltage fluctuation and was synchronized at 17:18. It again tripped at 17:44 due to excitation loss.	
f) Hasnabad-Shyampur 132kV line CVT blue phase burnt from Hasnabad end at 18:34. Due to this occurrence Meghnaghat-Hasnabad 230kV line-2, Hasnabad-Kamrangirchar 132kV line, Hasnabad-Kalyanpur 132kV line, Hasnabad-Sitalakhya 132kV line, Hasnabad-Shyampur 132kV line and Hasnabad 230/132 kV TR-1, TR-2 & TR-3 X-formers tripped showing E/F, 132/33 kV T2, T5 & T6 also tripped, Kalyanpur 132/33 kV T1, T2 & T3 X-formers tripped due to Main, Buchholz, PRD tripped, OLTC surge, O/C relay. These lines and X-formers were switched on at 19:10, 21:16, 21:17, 21:13, (Hasnabad-Shyampur line was not switched on), 20:32, 19:35, 21:35, 20:15, 20:20, 20:20, 20:55, 21:32, 18:58 respectively. Due to this occurrence Ghorasal RPP(45 MW) tripped at 18:43 QRPP(100 MW) tripped at 18:33, Haripur SBU GT-1, GT-2 tripped at 18:45, 18:48, DPA Pagla tripped at 18:35, Tongi GT tripped at 18:38. These machines were synchronized at 18:58, 18:49, 23:13, 22:51, 19:05, 18:58 respectively.	Power interruption occurred (about 204 MW) under Hasnabad, Kalyanpur & Sitalakhya S/S areas from 18:34 to 21:32..
g) Ghorasal-Joydevpur 132kV line-2 tripped at 18:36 from Ghorasal end showing remote protection trip and was synchronized at 18:50.	Due to generation shortage, about 63 MW (09:00) of load shed has been running since morning (05/03/11) over the whole area (except Sylhet, Dhaka, Barisal, Khulna) of the national grid.

Deputy / Asstt. Manager

Network Operation Division

Manager

Network Operation Division

Deputy General Manager

Load Despatch Circle