

QF-LDC-08  
Page -1

Description		Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.		So about 1241 MW (21:00) of load shed was imposed over the whole areas of the national grid .
b) Due to low gas pressure Baghabari 100 MW and RPCL (210 MW) were limited to 70 MW and 107 MW respectively.		
b) Rangpur 132/33 kV T1 X-former was under shut down from 08:30 to 09:10 due to red hot maint.		
c) Haripur-Comilla 132 kV line-1 & 2 were under shut down from 12:05 to 17:55 for making connection with 4 ckt tower towards newly constructed 132 kV Meghnaghat S/S.		
d) After maintenance Ashuganj CCPP GT-2 was synchronized at 17:12.		
e) After maintenance Khulna 110 MW was synchronized at 20:18.		
f) After maintenance Meghnaghat GT-1 & ST were synchronized at 20:40 & 22:18 respectively.		Due to generation shortage, about 460 MW (09:00) of load shed has been running since morning (16/03/11) over the whole area of the national grid.
Deputy / Asstt. Manager Network Operation Division	Manager Network Operation Division	Deputy General Manager Load Despatch Circle