

QF-LDC-08
Page -1

Reporting Date : 22-Mar-11
Hrs on 20-Aug-10

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

10671000 KWHR.

- KWHR.

Actual : 81.55 Ft.(MSL) , Rule curve : 89.64 Ft.(MSL)

HSD	:	1037185	Liter
FO	:	197285	Liter

Total : Tk97,088,813

Area	Yesterday		Today		
			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding
	MW		from to MW	MW	(On Estimated Demand)
Dhaka	420	(17:50-Till Now, Gen. shortage)	1945	370	19%
Chittagong Area	160	(17:50-Till Now, Gen. shortage)	560	138	25%
Khulna Area	136	(17:50-Till Now, Gen. shortage)	512	127	25%
Rajshahi Area	122	(17:50-Till Now, Gen. shortage)	420	104	25%
Comilla Area	78	(17:50-Till Now, Gen. shortage)	331	82	25%
Mymensing Area	74	(17:50-Till Now, Gen. shortage)	217	54	25%
Sylhet Area	17	(17:50-22:00, Gen. shortage)	223	22	10%
Barisal Area	17	(17:50-Till Now, Gen. shortage)	100	25	25%
Rangpur Area	63	(17:50-Till Now, Gen. shortage)	234	58	25%
Total	1087	21:00	4542	980	

Planned Shut-Down	Forced Shut-Down
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal 6(18/07/10)
2) Ghorasal 2(26/04/10)	2) Ashuganj-1(09/11/10)
3) Siddirganj GT-1 (18/06/10)	3) Khulna-110 MW(17/03/11)
4) Ashuganj-4(12/09/10)	4) B.Pukuria #2 (17/03/11)
5) Raozan-1 (03/10/10)	
6) Kaptai #5 (02/11/10)	
7) Kaptai #3 (1/12/10)	

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 1087 MW (21:00) of load shed was imposed over the whole areas of the national grid .
b) Due to low gas pressure Baghabari 100 MW and RPCL (210 MW) were limited to 70 MW and 106 MW respectively.	
c) Baghabari WMPL #1 tripped at 09:25 due to generator breaker open and was synchronized at 13:30.	
d) Ghorasal QRPP (100 MW) tripped at 11:09 due to tripping of Ghorasal S/S - Ghorasal QRPP 132kV line.	
e) After maintenance MPL (450 MW) GT-1, GT-2 & ST were synchronized at 11:29, 16:15 & 12:41 respectively.	
f) Comilla(N) - Hathazari 230kV Line-2 was under shut down from 08:30 to 16:44 due to annual maint.	
g) Joydevpur 132/33 kV T2 X-former was under shut down from 09:05 to 18:20 due to oil leakage maintenance.	
h) Baghabari 230/132 kV TR-1 is under shut down since 10:16 due to project work.	
i) Ghorasal 132 kV bus coupler tripped at 11:08 showing O/C relay and was switched on at 11:13. It again tripped at 12:05 showing same relay and was switched on at 12:25.	
j) Joydevpur-Ghorasal 132kV line-1 & 2 tripped at 11:08 from Joydevpur end operating SOTF, MVTR & MVGL MVTR & MVGL relays and was switched on at 11:20. It again tripped at 12:05 operating same relays and was switched on at 12:26	
k) Ghorasal-Rampura 230kV line-1 was under shut down from 15:30 to 16:46 due to SCADA interfacing work.	
l) Sikalbaha GT (150 MW) was synchronized at 18:55.	
l) After maintenance Fenchuganj GT-2 was synchronized at 19:57.	
m) Baghabari WMPL is under shut down since 00:16(22/03/11) due to Combustion inspection and water wash.	
n) Chatak 132/33 kV T2 X-former tripped at 23:36 due to tripping of 33 kV REB Shunamganj feeder and was switched on at 23:41. It again tripped at 07:16(22/03/11) due to same reason and was switched on at 07:21 (22/03/11).	
o) MPL (450 MW) GT-2 tripped at 03:23(22/03/11) due to turbine vibration high and was synchronized at 05:27 (22/03/11).	
p) MPL (450 MW) ST unit was forced shut down at 06:48 (22/03/11) due to turbine valve maint.	

Due to generation shortage, about 680 MW (09:00) of load shed has been running since morning (22/03/11) over the whole area (Except Sylhet) of the national grid.

Deputy General Manager
Load Despatch Circle