

QF-LDC-08
Page -1

Description	Forced load shedded / Interrupted Areas
<p>a) There was generation shortage in the evening peak hour yesterday.</p> <p>b) Due to low gas pressure RPCL (210 MW) and HPL (350 MW) were limited to 118 MW & 298 MW respectively.</p> <p>c) Ashuganj CCPP GT1 & ST tripped at 22:02 due to turbine vibration.</p> <p>d) After maint.Sikalbaha GT(150 MW) was sync.at 12:10</p> <p>e) Ghorasal #4 was shut down at 23:30 due to boiler tube leakage.</p> <p>f) Baghabari-71 MW was shut down at 01:40(01/04/11) due to work in control system.</p> <p>g) Maniknagar-Haripur 132 kV ckt-2 was shut down at 08:32 to remove of nest and was switched on at 09:43.</p> <p>h) Baghabari 230/132 kV TR2 transformer was shut down at 08:47due to CT basement work and was switched on at 10:42.</p> <p>i) Aminbazar 230/132 kV TR3 transformer was shut down at 09:06 due to fire fighting equipment system and was switched on at 09:55.</p> <p>j) Maniknagar-Haripur 132 kV ckt-1 was shut down at 09:45 to remove of nest and was switched on at 10:14.</p> <p>k) Maniknagar-Matuail 132 kV line was shut down at 10:17 to remove of nest and was switched on at 10:47.</p> <p>l) Comilla(C)-Feni 132 kV line-1 tripped at 11:40 from Comilla end showing dist.protection & directional O/C relays and was switched on at 11:53.</p> <p>m) Mymensing 132/33 kV T3 transformer was shut down at 19:15 due to red hot maint.of bus isolator and was switched on at 20:03.</p> <p>n) Ashuganj-Seraiganj 230 kV line-2 tripped fromboth end at 04:47(01/04/11) showing distance relay and was switched on at 05:35(01/04/11).</p> <p>o) Ashuganj-Ghorasal 230 kV line-1 tripped at 04:47(01/04/11) from both end due to damage of LA(Y-phase) at Ashuganj end showing dist.relay.It is now under maint.</p>	<p>So about 218 MW (20:00) of load shed was imposed over the whole areas of the national grid .</p> <p>Power interruption occurred (about 20 MW) under Mymensing S/S areas from 19:15 to 20:03.</p>
<p>Deputy / Asstt. Manager Network Operation Division</p>	<p>Manager Network Operation Division</p>
	<p>Deputy General Manager Load Despatch Circle</p>