

QF-LDC-08  
Page -1

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday. b) Due to low gas pressure RPCL(210 MW) was limited to 129 MW. c) After maintenance Ashuganj CCPP ST was synchronized at 17:41. d) After maintenance Baghabari WMPL #1 was synchronized at 21:54.	So about 652 MW (20:00) of load shed was imposed over the whole areas of the national grid.
	Due to generation shortage, about 80 MW (09:00) of load shed has been running since morning (08/04/11) over the whole area (except Sylhet) of the national grid.

Deputy / Asstt. Manager  
Network Operation Division

Manager  
Network Operation Division

Deputy General Manager  
Load Despatch Circle