

QF-LDC-08  
Page -1

Description	Forced load shaded / Interrupted Areas
<p>a) There was generation shortage in the evening peak hour yesterday.</p> <p>b) Due to low gas pressure RPCL(210 MW) was limited to 143 MW.</p> <p>c) Ashuganj #5 tripped at 15:52 due to server problem and was synchronized at 20:47.</p> <p>d) Ashuganj CAPP ST was shut down at 12:17 due to busbar maint.and was synchronized at 15:36.</p> <p>e) Kallayanpur 132/33 kV T2 transformer was shut down at 09:15 due to protection system test and was switched on at 12:23.</p> <p>f) Ashuganj 132/33 T1 transformer was shut down at 09:31 due to hooking up 50 MW gas generator at Ashuganj and was switched on at 18:27.</p> <p>g) Ashuganj-Ghorasal 132 kV ckt-1 was shut down at 10:05 due to hooking up 50 MW gas generator at Ashuganj and was switched on at 18:16.</p> <p>h) Ashuganj 132 kV bus-2 was shut down at 10:20 due to hooking up 50 MW gas generator at Ashuganj and was switched on at 17:32.</p>	<p>So about 547 MW (21:00) of load shed was imposed over the whole areas of the national grid.</p>
	<p>Due to generation shortage, about 200 MW (09:00) of load shed has been running since morning (09/04/11) over the whole area (except Sylhet) of the national grid.</p>
Deputy / Asstt. Manager Network Operation Division	<p>Manager Network Operation Division</p> <p>Deputy General Manager Load Despatch Circle</p>