

QF-LDC-08
Page -1

Reporting Date : 24-Apr-11
Hrs on 20-Aug-10

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Water Level of Kaptai Lake at 6:00 A M on

Cost of the Consumed Fuel (PDB) :	Gas :	Tk62,168,727	Oil (PDB) :	Tk14,906,272	Total : Tk77,074,998
-----------------------------------	-------	--------------	-------------	--------------	----------------------

Information of the Generating machines under shut down.

Planned Shut-Down

Description	Forced load shaded / Interrupted Areas	
a) There was generation shortage in the evening peak hour yesterday.	<p>So about 522 MW (20:00) of load shed was imposed over the whole areas of the national grid.</p>	
b) Due to gas pressure low RPCL 210 MW was limited to 140 MW.		
c) After maintenance Ashuganj #2 was synchronized at 18:01.		
d) Comilla(N)-Haripur 132 kV ckt-2 was shut down at 10:42 due to testing & calibrating of measuring instrument at Megnaghat IEL and was switched on at 19:18.		
e) Khushi-Halishahar 132 kV ckt-2 was shut down at 08:59 due to annual maintenance and was switched on at 14:54.		
f) Tongi GT tripped at 10:43 due to high vibration and was synchronized at 12:04.		
g) Ashuganj 132 kV bus coupler breaker was shut down at 08:32 due to changing CT ratio from 400/1A to 800/1A and was switched on at 16:32.		
h) Comilla(N) 230/132 kV TR2 transformer was energized at 13:17 at 230 kV end.		
i) Comilla(N) 230/132 kV 75*3 MVA transformer(Newly Installed) was energized at 15:52.		
j) Mymensing 132/33 kV 50/75 MVA transformer(Newly Installed) was energized at 18:05	<p>Due to generation shortage, about 75 MW (09:00) of load shed has been running since morning (24/04/2011) over the whole area (except Sylhet) of the national grid.</p>	
k) Ghorasal-45 MW RPP tripped at 18:48 due to auxiliary power failure and was sync.at 19:31.		
Deputy / Asstt. Manager Network Operation Division	Manager Network Operation Division	Deputy General Manager Load Despatch Circle