

QF-LDC-08
Page -1

Description		Forced load shedded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.		So about 799 MW (20:00) of load shed was imposed over the whole areas of the national grid (Except Khulna).
b) Due to low gas pressure Siddirganj 105 MW and RPCL 210 MW were limited to 65 and 125 MW respectively.		
c) Joydevpur 132/33 kV T2 transformer was under shut down from 09:05 to 17:40 due to maint.		Power interruption occurred (about 34 MW) under Dohazari S/S areas from 12:40 to 14:42.
d) Rangpur-Saidpur 132kV Ckt-2 was under shut down from 09:46 to 12:59 due to red hot maintenance of 132kV CT loop at Rangpur end.		
e) Aminbazar 230kV bus-1 was under shut down from 09:44 to 18:29 due to red hot maintenance of isolator loop.		
f) Dohazari 33kV bus was under shut down from 12:40 to 14:42 due to changing 33kV CB of Banshkhali 33kV feeder.		
g) After maintenance Ashuganj CCPP ST unit was synchronized at 18:09 and tripped at 18:22 due to unit breaker oil pressure low. It was again synchronized at 21:29.		
h) Bagerhat-Goalpara 132kV line tripped at 20:44 showing O/C and was switched on at 20:49.		
i) Siddhirganj PP GT-2 tripped at 22:50 due to unit transformer PRD operation and was synchronized at 02:19 (17/5/11).		
j) Comilla (N) 230/132 kV T-02(New) transformer was switched on at 14:30.		
		Due to generation shortage about 115 MW (09:00) of load shed has been running since morning (17/5/11) over the whole area (except Sylhet) of the national grid.

Deputy / Asstt. Manager Network Operation Division	Manager Network Operation Division	Deputy General Manager Load Despatch Circle
---	---------------------------------------	--