

QF-LDC-08
Page -1

Description	Forced load shed / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday. b) Due to low gas pressure HPL 360 MW and RPCL 210 MW were limited to 302 and 113 MW respectively. c) Siddirganj GT2 was forced shut down at 10:38 due to gas booster problem and was synchronized at 16:29. d) Thakurgaon RPP tripped at 12:10 showing O/C relay and was synchronized at 12:11 and again tripped 12:45 due to the same reason and was synchronized at 10:05(19/5/11). e) Khulna-110 MW was forced shut down at 00:46(19/5/11) due to leakage of CW pump. f) Maniknagar-Narinda 132 kV U/C ckt-2 was shut down at 08:44 due to relay maintenance and was switched on at 10:20. g) Megnaghat-Comilla(N) 230 kV ckt-2 was shut down at 11:00 due to S/S work at Megnaghat end and was switched on at 12:29. h) Mirpur-Uttara 132 kV ckt was shut down at 08:45 due to tower deflection checking and was switched on at 16:46. i) Mirpur-Tongi 132 kV ckt was shut down at 08:50 due to tower deflection checking and was switched on at 17:11. j) Ishurdi 132/33 kV T1 transformer was shut down at 08:35 due to red hot maintenance and was switched on at 12:07. k) Bhandaria-Barisal 132 kV ckt tripped at 12:16 showing distance & E/F relays and was switched on at 12:20. l) Ashuganj-Ghorasal 132 kV ckt-2 tripped at 21:33 showing distance relay from both end. m) Ishurdi-Ghorasal 230 kV ckt-1 tripped at 03:20(19/5/11) from both side showing PTAW, PD3,DRST and was switched on at 04:18(19/5/11) n) Ghorasal-Bulta 132 kV ckt tripped at 04:28(19/5/11) showing protection relay and was switched on at 07:38(19/05/11). o) Haripur-Narsingdi 132 kV ckt tripped at 04:50(19/5/11) showing distance zone-2 and was switched on at 05:12(19/5/11). p) Ghorasal- Narsingdi 132 kV ckt tripped at 04:28(19/5/11) showing distance protection relay and was switched on at 07:45(19/5/11). q) Faridpur-Madaripur 132 kV ckt-1 & 2 tripped at 03:28 & 04:38(19/5/11) showing E/F & O/C relays and were switched on at 05:08 & 08:22(19/5/11) respectively. r) Bagerhat- Bhandaria 132 kV ckt tripped at 04:38(19/5/11) showing distance ABC and was switched on at 05:40(19/5/11). s) Bagerhat-Mongla 132 kV ckt tripped at 04:38(19/5/11) due to over voltage and was	<p>So about 1005 MW (21:00) of load shed was imposed over the whole(except-Mymensing,Sylhet & Barisal) areas of the national grid.</p> <p>Power interruption occurred (about 12 MW) under Narsingdi S/S area from 04:50 to 05:12.</p> <p>Power interruption occurred (about 98 MW) under Madaripu,Bhandaria, Gopalganj S/S areas from 04:38 to 05:08.</p> <p>Power interruption occurred (about 14 MW) under Mongla S/S area</p>

switched on at 07:06(19/05/11).
t) Jhenidah-Bottail 132 kV ckt-1 & 2 tripped at 05:15(19/5/11) showing distance ABC and
were switched on at 05:48 & 05:54(19/5/11) respectively.

Deputy / Asstt. Manager
Network Operation Division

Manager
Network Operation Division

from 04:38 to 07:06.

Deputy General Manager
Load Despatch Circle