POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTEF DAILY REPORT

4698.5 MW at Till now the maximum generation is: on 20-Aug-10 16-Sep-10) Generation & Demand Today's Actual Min Gen. & Probable Gen. & De The Summary of Yesterday's (Day Peak Generation 3608.0 MW Hour Min Gen. at 3061 Evening Peak Generation 4290.0 MW Max Generation 4390 Hour 20:00 MW 4700 E.P. Demand (at gen end) : 4700.0 20:00 Max Demand Hour : Maximum Generation 4290.0 MW Hour 20:00 Shortage 310 85.41% Total Gen. (MKWH) 89.79 System L/ Factor Load Shed 274

EXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid: Maximum 660 MW at 1:00 Energy 13461000 Import from West grid to East grid: Maximum - MW at - Energy -

Water Level of Kaptai Lake at 6:00 A M of 17-Sep-10

Actual: 106.97 Ft.(MSL), Rule curve: 102.68 Ft.(MSL)

Gas Consumed : Total 745.62 MMCFt. Oil Consumed (PDB) :

HSD : 1532568

17-Sep-10

FO : 0

Reporting Date :

Cost of the Consumed Fuel (PDB): Gas : Tk55,108,774 Oil : Tk61,302,700 Total : Tk116,411,474

Load Shedding & Other Information

Area	Yesterday		Today		
,,,,,			Estimated Demand(s/s end)	Estimated Shedding (s/s e	Rates of Sheddi
	MW		from toMW	MW	(On Estimated De
Dhaka	149	(18:05-23:00 gen. shortage)	1812	98	5%
Chittagong Area	53	(18:05-00:20 gen. shortage)	503	42	8%
Khulna Area	40	(18:05-23:50 gen. shortage)	458	38	8%
Rajshahi Area	45	(18:05-00:22 gen. shortage)	376	31	8%
Comilla Area	28	(18:05-23:56 gen. shortage)	297	25	8%
Mymensing Area	20	(18:05-23:56 gen. shortage)	196	16	8%
Sylhet Area	-	0	217	-	-
Barisal Area	8	(18:05-23:50 gen. shortage)	89	7	8%
Rangpur Area	20	(18:05-23:53 gen. shortage)	209	17	8%
Total	363	20:00	4157	274	

Information of the Generating machines under shut down.

Planned Shut- Down		Forced Shut- Down
	1) Kaptai- 3 (19/04/08)	8) Ashuganj-4(12/09/10)
	2) Khulna 110MW (31/03/09)	9) Barapukuria 1 & 2 (13/09/10)
	3) Haripur SBU GT-3 (18/06/09)	
	4) Ghorasal 2(26/04/10)	
	5) Siddirganj GT-1 (18/06/10)	
	6) Ghorasal 6(18/07/10)	
	7)Ghorasal-5(12/09/10)	

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour vesterday.	So about 126 MW (21:00) of load shed was imposed

- a) There was generation shortage in the evening peak hour yesterday.
- b) Due to low gas pressure Raozan (360 MW) and Tongi GT (105 MW) were limited to 340 MW, 0 MW respectively.
- c) After maintenance Barapukuria #1 was synchronized at 19:20.It again tripped at 21:15 due to turbine vibration excessive and was synchronized at 22:35.
- d) Kaptai # 2 tripped at 10:15 due to under impedance and was synchronized at 10:42.It again tripped at 15:50 due to governor oil head vibration and was synchronized at 15:55.It again forced shut down at 17:20 due to governor oil head vibration and was synchronized at 19:40.
- f) Ashuganj CCPP GT-1 & St tripped at 20:53 due to turbine vibration excessive
- g) Sikalbaha GT(150 MW) was synchronized at 18:47 and was shut down at 20:10.
- h) Hathajari Feni 132 KV line 1 & 2 tripped at 11:54 (line-1 at Hathazari end & line-2 at Feni end) showing following relays: distance relay-Z3, E/F- Z2 at Hathazari end and C.B 1,A/R fail,PCSR at Feni end .Line-1 was switched on at 12:13 and line-2 was switched on at 12:32.
- i) Comilla Feni 132 KV line-1 tripped at both end showing distance protection directional E/F, A/R fail and was switched on at 12:20.
- j) Comilla (N) Comilla (S) 132 KV line tripped at 11:56 showing distance protection directional E/F, directional over current relay was switched on at 12:28.
- k) Chandpur Chowmuhani 132 KV line-1 & 2 tripped at 11:55 showing E/F at line-2 (line-1 was no signal) . Line-1 was switched on at 12:12 and line-2 was switched on at 12:19.
- I) Ghorasal Joydevpur 132 KV line-2 tripped at 00:12(17/9/10) showing remote protection relay and was switched on at 00:24(17/9/10).
- m) Tongi Kabirpur 132 KV line-1 & 2 tripped at 00:15 (17/9/10) showing dist,Z-1,CSW & CE relays and was switched on at 00:20(17/9/10).
- n) Kabirpur 132 /33 KV T1 X-former was tripped at 00:15 (17/9/10) due to breaking of lightning arrester and was switched on (bypass) at 01:05 (17/9/10).
- o) Shahjibazar 86 MW was tripped at 02:51(17/9/10) showing E/F and was synchronized at 09:30 (17/9/10).

So about 126 MW (21:00) of load shed was impossible (except Sylhet) areas of the national grid.

Power interruption occurred (about 52 MW) under Cl from 11:55 to 12:19.

Deputy / Asstt. Manager Network Operation Division

emand	
MW	
IVIVV	
KWHR.	
KWHR.	
Liter	
Liter	
ing	
emand)	
l over the	
l over the	

howmuhani S/S areas