

QF-LDC-08  
Page -1

Reporting Date : 18-Sep-10  
Hrs on 20-Aug-10

### EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Water Level of Kaptai Lake at 6:00 A M of

Actual : 107.00

HSD	:	1484361	Liter
FO	:	0	Liter

Oil : Tk59,374,428

### Load Shedding & Other Information

Area	Yesterday		Today		
			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding
	MW		from to MW	MW	(On Estimated Demand)
Dhaka	57	(18:15-22:05 gen. shortage)	1858	101	5%
Chittagong Area	18	(18:15-22:07 gen. shortage)	525	52	10%
Khulna Area	15	(18:15-22:35 gen. shortage)	478	48	10%
Rajshahi Area	18	(18:15-22:30 gen. shortage)	393	39	10%
Comilla Area	10	(18:15-22:02 gen. shortage)	309	30	10%
Mymensing Area	11	(18:15-22:02 gen. shortage)	204	19	9%
Sylhet Area	-	0	222	-	-
Barisal Area	9	(18:15-22:35 gen. shortage)	93	9	10%
Rangpur Area	12	(18:15-22:30 gen. shortage)	218	21	10%
Total	150	20:00	4300	319	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
	1) Kaptai- 3 (19/04/08)
	2) Khulna 110MW (31/03/09)
	3) Haripur SBU GT-3 (18/06/09)
	4) Ghorasal 2(26/04/10)
	5) Siddirganj GT-1 (18/06/10)
	6 ) Ghorasal 6(18/07/10)
	7)Ghorasal-5(12/09/10)
	8) Ashuganj-4(12/09/10)

**Additional Information of Machines, lines, Interruption / Forced Load shed etc.**

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 150 MW (20:00) of load shed was imposed over the whole (except Sylhet) areas of the national grid .
b) Due to low gas pressure Raozan (360 MW) and Tongi GT (105 MW) were limited to 340 MW, 0 MW respectively.	
c) Sikalbaha GT (150 MW) was synchronized at 13:30.	Power interruption occurred (about 19 MW) under Narsingdi S/S areas from 11:27 to 14:22.
d) Baghabari WMPL #1 & #2 tripped at 11:46 showing E/F .Unit #1 was synchronized at 14:57 and #2 was synchronized at 15:31.	
e) After maintenance Barapukuria #2 was synchronized at 15:20.	
f) After maintenance Ashuganj CCPP st was synchronized at 17:02.	
g) Shahjibazar GT-8 tripped at 17:55 due to generator protection trip and was synchronized at 19:30.	
h) Kaptai #5 was forced shut down at 20:45 due to thrust bearing oil cooler leakage .	
i) Fenchuganj (90 MW) GT-1 & st tripped at 22:55 due to tripping of cooling water pump and GT-1 was synchronized at 00:55(18/9/10).	
j) Ishurdi - Ghorasal 230 KV line-2 tripped at 11:48 showing LZ 96, DST,PD3,PEAW at Ishurdi end ;dst, PTA5, PD3, PTAW relays at Ghorasal end and was switched on at 12:45.	
k) Hasnabad - Kamrangirchar 132 KV line tripped at 17:57 showing A/R fail, main protection trip, dst relays and was switched on at 19:06.	
l) Narsingdi 132/33 KV X-former was shut down at 11:27 due to CT problem and was switched on at 14:22.	

Deputy General Manager  
Load Despatch Circle