

## DAILY REPORT

Page -1

Till now the maximum generation is :- **5243.5 MW** at **22:00** Hrs on **29-Aug-11** Reporting Date : **1-Sep-11**

The Summary of Yesterday's ( 31-Aug-11 )		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	3617.0	MW	Hour :	12:00	Min. Gen. at	8:00	3220 MW
Evening Peak Generation :	4882.5	MW	Hour :	21:00	Max Generation	:	5114 MW
E.P. Demand (at gen end) :	4882.5	MW	Hour :	21:00	Max Demand	:	5114 MW
Maximum Generation :	4882.5	MW	Hour :	21:00	Shortage	:	0 MW
Total Gen. (MKWH) :	95.41	System L Factor	:	85.41%	Load Shed	:	0 MW

## EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :-	Maximum	770	MW	at	3:00	Energy	14.030	MKWHR.
Import from West grid to East grid :-	Maximum	-	MW	at	-	Energy	-	MKWHR.
Water Level of Kaptai Lake at 6:00 A M on				1-Sep-11				
Actual :	104.12	Ft.(MSL) ,	Rule curve :		99.00	Ft.( MSL )		

Gas Consumed :	Total	748.92	MMCFD.	Oil Consumed (PDB) :	HSD :	Liter
					FO :	Liter

Cost of the Consumed Fuel (PDB+Pvt) :	Gas :	Tk59,804,250	Oil :	Tk127,139,709	Total :	Tk195,009,781
	Coal :	Tk8,065,821				

## Load Shedding &amp; Other Information

Area	Yesterday		Today		Rates of Shedding (On Estimated Demand)
	MW		Estimated Demand(s/s end) from to MW	Estimated Shedding (s/s end) MW	
Dhaka	-	0	1837	-	-
Chittagong Area	-	0	486	-	-
Khulna Area	-	0	547	-	-
Rajshahi Area	-	0	493	-	-
Comilla Area	-	0	362	-	-
Mymensing Area	-	0	268	-	-
Sylhet Area	-	0	266	-	-
Barisal Area	-	0	87	-	-
Rangpur Area	-	0	275	-	-
<b>Total</b>	<b>0</b>		<b>4621</b>	<b>0</b>	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal 6(18/07/10)
2) Ghorasal 2(26/04/10)	2) Ashuganj-1(09/11/10)
3) Siddhirganj GT-1 (18/06/10)	3) Raozan-2 (26/03/11)
5) Kaptai #3 (1/12/10)	4) WMPL #2(1/8/11)
6) Shahjibazar #8,9 (1/9/11)	5) Bhola RPP (18/7/11)
	6) Siddhirganj ST 210 MW (1/8/11)
	7) Sylhet-20(26/7/11)
	8) Ashuganj #2(29/7/11)
	9) Sikalbaha GT 150 MW (13/7/11)
	10) Sikalbaha ST(21/8/11)
	11) Shahjibazar #5 & 6(21/7/11)
	12) Baghabari 71 MW (1/9/11)

## Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) Faridpur-Bheramara 132 kV Ckt-1 was under shut down from 12:02 to 13:54 due to red hot maintenance at wave trap at Faridpur end.	
b) Pabna 132/33 kV T1 & T2 transformer tripped at 17:15 showing E/F relay and was switched on at 20:20 & 20:35 respectively.	Power interruption occurred (about 27 MW) under Pabna S/S areas from 17:15 to 20:20.
c) Bhandaria 132/33 kV T1 & T2 transformer tripped at 18:34 showing E/F & over load relay respectively and were switched on at 19:08 & 18:37 respectively.	Power interruption occurred (about 20 MW) under Bhandaria S/S areas from 18:34 to 18:37.
d) Ashuganj #3 was forced shut down at 22:35 due to HP heater problem.	
e) Baghabari 230/132 kV Tr-2 transformer tripped at 02:06 (1/9/11) showing buchholz relay.	
f) Bhandaria 132/33 kV T1 is under shut down since 07:50 (1/9/11) due to CT maintenance.	

Deputy / Asstt. Manager  
Network Operation Division

Manager  
Network Operation Division

Deputy General Manager  
Load Despatch Circle