POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

MW

Oil Consumed (PDB):

whole areas of the national grid.

from 08:25 to 09:05.

QF-I DC-08 Page -1

Reporting Date: 8-Sep-11 Till now the maximum generation is : 5243.5 WWW at Hrs 29-Aug-11 The Summary of Yesterday's (7-Sep-11) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 4379.0 MW Hour : 11:00 Min. Gen. at 7:00 3486 MW Evening Peak Generation 4838.5 MW 4930 Hour 21:00 Max Generation MW E.P. Demand (at gen end) : 5400.0 MW Max Demand 5500 MW Maximum Generation 4839.0 MW Hour 23:00 Shortage 570 MW Total Gen. (MKWH) 103.55 System I / Factor 85.41% Load Shed 519 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 700 MW MKWHR. at 3:00 Energy 13.872

Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 6:00 A M on 8-Sep-11

MMCFD.

Ft.(MSL) 100.61 Ft.(MSL) Rule curve :

HSD

Energy

FO Liter

MKWHR

Cost of the Consumed Fuel (PDB+Pvt) : Tk61.212.875

766.56

105.25

Actual

Gas Consumed :

Tk4,202,125

Load Shedding & Other Information

Area	Yesterday	Today			
"			Estimated Demand(s/s end)	Estimated Shedding (s/s e	n Rates of Shedding
	MW		from tonW	MW	(On Estimated Demand)
Dhaka	210	18:40-22:55	1945	158	8%
Chittagong Area	80	18:40-22:26	538	67	12%
Khulna Area	62	18:40-22:25	605	75	12%
Rajshahi Area	38	18:40-22:16	546	68	12%
Comilla Area	35	18:40-22:30	401	50	12%
Mymensing Area	29	18:40-22:15	297	37	12%
Sylhet Area	22	18:40-22:15	273	15	5%
Barisal Area	10	18:40-22:25	95	11	12%
Rangpur Area	25	18:40-22:16	305	38	12%
Total	511	21:00	5005	519	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut-Down
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal 6(18/07/10) 8) Ashuganj #2(29/7/11)
2) Ghorasal 2(26/04/10)	2) Ashuganj-1(09/11/10) 9) Sikalbaha GT 150 MW (13/7/11)
3) Siddirganj GT-1 (18/06/10)	3) Raozan-2 (26/03/11) 10) Sikalbaha ST(21/8/11)
4) Kaptai #3 (1/12/10)	4) WMPL #2(1/8/11) 11) Shahjibazar #5 & 6(21/7/11)
	5) Bhola RPP (18/7/11) 12) Ghorasal #3 (4/9/11)
	6) Siddhirganj ST 210 MW (1/8/11) 13) Ashuganj CCPP ST(30/8/11)
	7) Sylhet-20(26/7/11) 14) Ashuganj CCPP GT-1(7/9/11)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 511 MW (21:00) of load shed was imposed over the

- b) Due to low gas pressure RPCL-210 MW was limited to 121 MW.
- c) Khulna(S) 230/132 kV T01 & T02, Khulna(S)-Khulna(C) 132 kV ckt-2, Khulna(S)- KPCL-2 132 kV ckt, Khulna(S)-Satkhira 132 kV ckt, Khulna(S)-Gollamari 132 kV ckt-1 & 2 all tripped at 08:25 due to burst of 132 kV capacitor bank breaker B-phase bushing showing busbar protection. At that time all running machines under Khulna zone-KPCL(1 & 2) , KPCL-2, Noapara (40 MW) RPP, Noapara(Quantum)RPP, Khulna-110 MW, 60 MW also tripped. The ckts were switched on at 09:50,09:44,09:52,09:49,09:46,09:48 & 09:48 respectively.

Deputy / Asstt. Manager

Network Operation Division

The machines were synchronized at 08:46, 10:15, 11:25 & 08:45 respectively.

Manager Network Operation Division

Load Despatch Circle

Power interruption occurred (about 324 MW) under Khulna & Barisal zone

Deputy General Manager