

Month : Sep-2011 Day : Tuesday Date : 27-Sep-11

Probable Maximum Generation :		(a) At Day Peak Hour :		MW		(b) At Evening Peak Hour :		4650 MW						
Water Level of Kapital Lake at 06:00 AM		(a) Yesterday :		108.43 ft		(b) Today :		108.34 ft						
		(c) Rule Curve :		105.04 ft										
Sl.	Name of the Power Station	Fuel	Producer	Installd Capacity		Deraled / Present Capacity	Actual Generation		Available Generation		Ev. Peak Gen Shortfall		Plants under Shut down (Date) / Remarks	Probable Start up Date
				MW	MW		Day Peak	Ev. Peak	Day Peak	Ev. Peak	for Fuel Limitation	for Plants S/D or M/C prob.		
1a	Ghorasal ST 1 & 2	Gas	PDB	2X55	110	85	0	0	0	0	85		#1(26/04/10), #1(25/9/11)	#1(28/9/11)
1b	Ghorasal ST 3,4,5& 6	Gas	PDB	4X210	840	760	290	290	290	290	360		#6(18/07/10), #4(20/9/11)	#4(21/01/11)
2	Ghorasal 100 MW	HSD	ORPP 3yrs	128X0.85	100	100	103	100	102	100				
3	Ghorasal 45 MW	HSD	ORPP 3yrs	50X0.85	45	45	45	46	44	45			Synchronized at 33KV	
4	Ghorasal MAX	Gas	RPP	4x19.6	78	78	34	73	39	73				
5	Haripur SBU GT 1, 2 & 3	Gas	SBU,PDB	3x33.33	100	96	55	55	55	55	35		#3(18/06/09)	Unknown
6	Haripur NEPC	HFO	IPP	8x15	110	110	38	51	38	51	59			
7	Haripur P. Ltd CCPP	Gas	IPP	235+125	360	360	347	321	298	321	39			
8	Meghnaghat P.Ltd CCPP	Gas	IPP	3X150	450	450	222	445	445	445				
9	Meghnaghat IEL	HFO	RPP	12x8.9	100	100	78	77	77	77	23			
10	Madanganj 102 MW	HFO	ORPP 3yrs	6x17.08	102	102	100	100	100	100				
11	Narshingdi	Gas	SIPP,REB	8X2.90	22	22	19	22	22	22			Synchronized at 33KV	
11a	Siddhirgonj ST	Gas	EGCB	1x210	210	150	0	0	0	0	150		8/12/2011	Unknown
11b	Siddhirgonj GT-1, 2	Gas	EGCB	2x120	210	210	90	56	45	56	154		GT-1 is On test	
12	Siddhirgonj 100MW	HSD	ORPP 3yrs	96x1.2	100	100	79	84	51	84	16			
13	Dutch Bangla 100 MW	HFO	RPP	12x8.9	100	100	93	92	92	92				
14	DPA Power 50MW	HSD	ORPP 3yrs	100X0.5	50	50	34	34	33	34	16		Synchronized at 33KV	
15	Summit Power (Dhaka)	Gas	SIPP,REB		150	150	92	85	91	90			Synchronized at 33KV	
16	Tongi GT	Gas	PDB	1X 105	105	105	0	0	0	0	105			
<b>Dhaka Area Total</b>				<b>3342</b>	<b>3173</b>	<b>1719</b>	<b>1931</b>	<b>1822</b>	<b>1935</b>	<b>314</b>	<b>728</b>			
1	Chittagong Roazan ST 1 & 2	Gas	PDB	2x210	420	360	130	130	130	130	50		#2 (26/3/11)	Unknown
2	Kaptai Hydro unit 1,2,3,4&5	PDB		2X40+3X50	230	230	179	179	179	179	50		#3(1/12/10)	#3(5/12/11)
3a	Sikalbaha ST	Gas	PDB	1X60	60	40	0	0	0	0	40		9/14/2011	Unknown
3b	Sikalbaha GT	Gas	PDB	1x150	150	150	0	0	0	0	150		7/13/2011	Unknown
4	Sikalbaha	HFO	RPP 3yrs	4X12.5+2X11.9+1X3.1	55	55	8	24	16	24	31			
5	Barabkunda	Gas	SIPP,PDB	8X2.90	22	22	20	20	22	20			Synchronized at 33KV	
6	Malancha, Ctg EPZ	Gas	PDB		33	33	3	29	3	29			Synchronized at 33KV	
<b>Chittagong Area Total</b>				<b>970</b>	<b>890</b>	<b>340</b>	<b>382</b>	<b>350</b>	<b>382</b>	<b>50</b>	<b>451</b>			
1a	Ashuganj ST 1,2	Gas	APSCL	2x64	128	128	0	0	0	0	128		#1(9/11/10),2(29/7/11)	Unknown #2(30/9/11)
1b	Ashuganj ST 3,4,5	Gas	APSCL	3x150	450	385	370	395	395	395				
1c	Ashuganj CCPP	Gas	APSCL	2x56+34	146	98	40	73	91	91				
1d	Ashuganj 50 MW	Gas	APSCL	16x3.35	50	50	53	53	53	50				
2	Ashuganj	Gas	RPP 3yrs	15x4	55	55	50	55	57	55				
3	Ashuganj Aggrekko	Gas	RPP	82x1.1	80	80	81	81	80	80				
4	Ashuganj UP-53 MW	Gas	RPP	14x4	53	53	53	53	53	53				
5	Brahmanbaria 70MW	Gas	ORPP 3yrs	72x1	70	70	68	68	67	68				
6	Bauckandi 50 MW	FO	PDB	6x8.92	50	50	0	0	0	0			On test	
7	Feni	Gas	SIPP,PDB	8X2.90	22	22	19	19	20	19			Synchronized at 33KV	
8	Mahipal,Feni	Gas	SIPP,REB	4X2.90	11	11	11	11	11	11			Synchronized at 33KV	
9	Jangalia	Gas	SIPP,PDB	4X8.73	33	33	30	33	26	33			Synchronized at 33KV	
10	Summit Power (Comilla)	Gas	SIPP,REB		21	21	9	10	6	10	11		Synchronized at 33KV	
<b>Comilla Area Total</b>				<b>1169</b>	<b>1056</b>	<b>784</b>	<b>851</b>	<b>859</b>	<b>865</b>	<b>0</b>	<b>139</b>			
1	RPCL CCPP,Mymensing	Gas	IPP	4X35+1x70	210	175	106	106	107	106	69			
2	Tangail	Gas	SIPP,PDB	8X2.90	22	22	22	22	22	22			Synchronized at 33KV	
<b>Mymensing Area Total</b>				<b>232</b>	<b>197</b>	<b>128</b>	<b>128</b>	<b>129</b>	<b>128</b>	<b>69</b>	<b>0</b>			
1a	Fenchuganj CCPP (old)	Gas	PDB	2x32+1x33	97	91	88	88	84	88				
1b	Fenchuganj CCPP (new)	Gas	PDB	2x35+1x35	105	90	30	30	30	30			On test	
2	Fenchuganj	Gas	RPP 15yrs	19X2.90	51	50	47	50	47	50				
3	Fenchuganj Prima 50 MW	Gas	RPP		50	50	13	27	23	27			On test	
4	Hobiganj	Gas	SIPP,REB	4X2.90	11	11	11	11	11	11			Synchronized at 33KV	
5	Shahjibazar GT 5,6,8,9	Gas	PDB	2X15+2X35	100	89	61	63	63	63	20		#5.6 (21/8/11)	Unknown
6	Shahjibazar 86 MW	Gas	RPP 15yrs	32X2.90	86	86	89	89	89	86				
7	Shahjibazar 50 MW	Gas	RPP 3yrs	27X2.0	50	50	44	49	48	49				
8	Sylhet GT	Gas	PDB	1X20	20	20	0	0	0	0	20		Synchronized at 33KV(26/7/11)	Unknown
9	Sylhet 50MW	Gas	RPP 3yrs	29x1.95	50	50	39	38	37	40				
10	Sylhet 11 MW	Gas	RPP 15yrs	6X1.95	10	10	8	10	10	10			Synchronized at 33KV	
<b>Sylhet Area Total</b>				<b>630</b>	<b>597</b>	<b>430</b>	<b>455</b>	<b>442</b>	<b>454</b>	<b>0</b>	<b>40</b>			
1	Bheramara GT 1, 2 & 3	HSD	PDB	3X20	60	54	0	46	0	46				
2	Bheramara	HSD	RPP 3yrs	120x5+2x6+2x13	110	100	45	50	50	50	50			
3a	Khulna ST 110MW	FO	PDB	1X110	110	60	52	52	50	52				
3b	Khulna ST 60MW	FO	PDB	1X60	60	35	0	0	0	0	30		9/10/2011	Unknown
4	KPCL, Khulna	HFO	IPP	19x6.5	110	106	108	114	102	106				
5	KPCL, Khulna (new)	HFO	IPP	7x17	115	115	115	117	117	115				
6	Fandpur	FO	PDB	8x6.89	50	50	0	0	0	0			On test	
7	Gopalganj 110 MW	HFO	PDB	16x6.98	109	109	0	0	0	0			On test	
8	Noapara (105 MW) Quantam	HFO	RPP	9.9x5+9.5x6+9.2x2	105	105	30	36	25	36	69			
9	Noapara (40 MW),KZA	HFO	RPP	5x8	40	40	8	8	8	8				
10	Khulna 40 MW	HSD	RPP 3yrs	50X0.80	40	40	40	41	40	40				
11	Khulna 55 MW	HSD	ORPP 3yrs	71X0.85	55	55	53	56	28	55			Synchronized at 33KV	
<b>Khulna Area Total</b>				<b>964</b>	<b>869</b>	<b>451</b>	<b>520</b>	<b>420</b>	<b>508</b>	<b>0</b>	<b>149</b>			
1	Barisal Diesel	HSD	PDB	2X1.4+2X1.35	5	3	0	0	0	0				
2	Barisal GT 1 & 2	HSD	PDB	2X20	40	32	0	31	0	31				
3	Bhola	Gas	RPP 3yrs	1X34.50	33	33	0	0	0	0	33		7/18/2011	Unknown
<b>Barisal Area Total</b>				<b>78</b>	<b>68</b>	<b>0</b>	<b>31</b>	<b>0</b>	<b>31</b>	<b>0</b>	<b>33</b>			
1a	Baghabari GT 1	Gas	SBU,PDB	1X71	71	71	67	68	68	68	10			
1b	Baghabari GT 2	Gas	SBU,PDB	1X100	100	100	97	90	94	90				
2	Baghabari 50 MW	HFO	PDB	6x8.9	50	50	9	9	9	9			On test	
3	Baghabari Westmont	Gas	IPP	2X45	90	70	35	36	35	36	35		2/18/11	Unknown
4	Bera 70 MW	HFO	PDB	9x8.29	71	71	9	7	9	0			On test	
5	Amnura 50 MW	HFO	RPP	7x7.79	50	50	0	0	9	0			On test	
6	Bogra GBB	Gas	RPP 15yrs	6X4	21	21	21	21	18	21			Synchronized at 33KV	
7	Bogra 20MW	Gas	RPP 3yrs		20	20	9	10	9	10			On test	
8	Summit Power (Ullapara)	Gas	SIPP,REB	4X2.90	11	11	0	8	8	8			Synchronized at 33KV	
<b>Rajshahi Area Total</b>				<b>484</b>	<b>464</b>	<b>247</b>	<b>249</b>	<b>259</b>	<b>242</b>	<b>10</b>	<b>35</b>			
1	Barapukuria ST 1 & 2	Coal	PDB	2x125	250	220	60	60	60	60	160		#1(2/9/11)	#1(30/9/11)
2	Rangpur GT	HSD	PDB	1X20	20	20	0	19	0	19				
3	Sayadpur GT	HSD	PDB	1X20	20	19	0	0	0	0				
4	Thakurgaon	HSD	RPP 3yrs	20X1.5+21X1.1	50	50	0	26	24	26			24	
<b>Rangpur Area Total</b>				<b>340</b>	<b>309</b>	<b>60</b>	<b>105</b>	<b>84</b>	<b>105</b>	<b>0</b>	<b>184</b>			
<b>Total</b>				<b>8209</b>	<b>7623</b>	<b>4159</b>	<b>4652</b>	<b>4365</b>	<b>4650</b>	<b>443</b>	<b>1759</b>			