POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

QF-LDC-08

			DAILY	REPORT				Page -1
				-	Rep	orting Date :	1-Oct-11	
Till now the maximum generation is : -		5243.5 WWW at		22:00	Hrs on	29-Aug-11		
The Summary of Yesterday's (30-Sep-11) Generation & Demand			Today's Actual I	Min Gen. & Prol	bable Gen. & I	Demand
Day Peak Generation :	4294.0	MW Hour :		9:00	Min. Gen. at	7:00	4128	MW
Evening Peak Generation :	4916.0	MW Hour :		20:00	Max Generation	n :	4803	MW
E.P. Demand (at gen end) :	5450.0	MW Hour :		20:00	Max Demand	:	5500	MW
Maximum Generation :	4934.0	MW Hour :		22:00	Shortage	:	697	MW
Total Gen. (MKWH) :	114.91	System L/ Factor :		85.41%	Load Shed	:	634	MW
	EXPOR	T/IMPORT THROUGH EAST	-WEST INTE	ERCONNECTOR	- -			
Export from East grid to West grid :- Maximum		530		MW at	21:00	Energy	8.791	MKWHR.
Import from West grid to East grid :- Maximum		-		MW at	-	Energy	-	MKWHR.
Water Le	vel of Kaptai Lak	e at 6:00 A M on		1-Oct-11				
Actual : 107.96 Ft.(MSL)	3		Rule cur	ve: 106.00	Ft.(MSL)			
Gas Consumed : Total	750.65	MMCFD.		Oil Consum	ed (PDR) ·			
	100.00			on consum	cu (1 DD) .	HSD :		Liter
						FO :		Liter
						10 .		LIGI
Cost of the Consumed Fuel (PDB+Pvt) : Gas	:	Tk59,942,3	98					
	Coal :	Tk4,117,5	18	Oil	: Tk259,495,857	Total : T	k323,555,773	3

Load Shedding & Other Information

Area Yesterd	Yesterday		Today				
			Estimated Demand(s/s end)	Estimated Shedding (s/s er	Rates of Shedding		
	MW		from to/W	MW	(On Estimated Demand)		
Dhaka	174	17:43-01:50	1960	218	11%		
Chittagong Area	60	17:43-01:40	535	76	14%		
Khulna Area	45	17:43-01:35	602	85	14%		
Rajshahi Area	58	17:43-01:49	542	77	14%		
Comilla Area	52	17:43-01:37	398	56	14%		
lymensing Area	28	17:43-01:35	295	42	14%		
Sylhet Area	23	17:43-22:30	276	25	9%		
Barisal Area	10	17:43-01:35	95	13	14%		
Rangpur Area	36	17:43-22:00	302	42	14%		
Total	486	20:00	5005	634			

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down		
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal 6(18/07/10)	9) Sikalbaha GT 150 MW (13/7/11)	
2) Ghorasal 2(26/04/10)	2) Ashuganj-1(09/11/10)	10) Sikalbaha ST 60MW (14/9/11)	
3) Kaptai #3 (1/12/10)	3) Raozan-2 (26/03/11)	11) Shahjibazar #5 & 6(21/7/11)	
	4) WMPL #2(1/8/11)	12) Khulna 60 MW (10/9/11)	
	5) Bhola RPP (18/7/11)	13) Ghorasal-4(20/9/11)	
	6) Siddhirganj ST 210 MW (1/8/	11)	
	7) Sylhet-20(26/7/11)	7) Sylhet-20(26/7/11)	
	8) Ghorasal-1(25/9/11)		

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description		Forced load shaded / Interrupted Areas		
a) There was generation shortage in the evenir	g peak hour yesterday.	So about 486 MW (20:00) of load shed was imposed over the		
b) Due to low gas pressure HPL 360 MW, Siddhirganj 210 MW, Raozan 210 MW and		whole areas of the national grid .		
RPCL 210 MW were limited to 340 MW, 100	MW, 130 MW and 106 MW respectively.			
c) Kabirpur 132/33 kV T1 transformer was under hot maintenance.	er shut down from 09:30 to 11:45 due to red			
 Kabirpur 132/33 kV T3 transformer was under hot maintenance. 	er shut down from 12:12 to 12:25 due to red			
 e) Jamalpur 132/33 kV T1 transformer was uno hot maintenance. 	er shut down from 10:25 to 10:55 due to red			
f) Mymensingh-Kishoreganj 132 kV Ckt-2 trippe switched on at 12:47.	ed at 12:44 showing dist. C-phase and was			
g) Noapara 132/33 kV T1 tripped at 18:41 show				
h) Noapara 132/33 kV T2 tripped at 18:41 showing O/C relay and was switched on at 18:57. At the same time Noapara RPP 40 MW also trip and was synchronized at 19:38.		Power interruption occurred (about 35 MW) under Noapara area from 18:41 to 18:57.		
i) After maintenance Ghorasal #1 was synchroi	nized at 21:03.			
 Kabirpur 132/33 kV T3 transformer was unde hot maintenance. 	r shut down from 21:40 to due to red			
k) Madunaghat-Kaptai Ckt-1 & 2 tripped at 18:3	0 due to damage of R-phase (2x11=22 pcs. Both ckt)			
& Y-phase (11 pcs. Ckt-1) disk insulator and	maintenance work is going on.			
I) Meghnaghat-Hasnabad 230 kV Ckt-1 was sh maintenance work at Hasnabad end. It was c	ut down at 03:22(1/10/11) due to harged at 04:10(1/10/11) from Meghnaghat end.			
m) Tongi-Aminbazar 230 kV Ckt-1 tripped at 06 R-phase relay and was switched on at 07:236	:29(1/10/11) from both end showing dist. Z1			
Deputy / Asstt. Manager	Manager	Deputy General Manager		
Network Operation Division	Network Operation Division	Load Despatch Circle		