POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

QF-LDC-08

Page -1 Reporting Date : 2-Nov-11 Till now the maximum generation is:-5243.5 NWW at 22:00 Hrs on 29-Aug-11 The Summary of Yesterday's (1-Nov-11) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand 12:00 Day Peak Generation 4127.0 MW Hour : Min. Gen. at 4:00 3239 MW Evening Peak Generation 4929.0 21:00 Max Generation 5050 MW Hour : E.P. Demand (at gen end) : 5200.0 MW 21:00 Max Demand 5200 MW Maximum Generation 4929.0 MW Hour : 21:00 Shortage 150 MW System I / Factor Total Gen. (MKWH) 95.41 85.41% Load Shed 138 MW EXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum MW 450 at 7:00 Energy 6.699 MKWHR. Import from West grid to East grid :- Maximum MKWHR. MW at Energy Water Level of Kaptai Lake at 6:00 A M on 2-Nov-11 Actual: 104.48 Ft.(MSL) Rule curve : 108.90 Ft.(MSL) Gas Consumed : Total 698.77 MMCFD. Oil Consumed (PDB): HSD : Liter FO : Liter Tk55.799.573 Cost of the Consumed Fuel (PDB+Pvt) : Oil : Tk190,387,835 Total : Tk254,055,812 Tk7,868,405

Load Shedding & Other Information

Area	Yesterday		Today		
			Estimated Demand(s/s end)	Estimated Shedding (s/s en	Rates of Shedding
	MW		from toMW	MW	(On Estimated Demand)
Dhaka	52	17:15-21:05	1869	-	-
Chittagong Area	34	17:15-21:01	510	25	5%
Khulna Area	40	17:15-21:15	575	29	5%
Rajshahi Area	46	17:15-21:05	520	28	5%
Comilla Area	25	17:15-21:05	382	21	5%
Mymensing Area	19	17:15-21:05	283	15	5%
Sylhet Area	14	17:15-21:02	279	-	-
Barisal Area	3	17:15-21:15	92	5	5%
Rangpur Area	17	17:15-21:05	290	15	5%
Total	250	21:00	4800	138	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down	
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal 6(18/07/10)	7) Sikalbaha ST 60MW (14/9/11)
2) Ghorasal 2(26/04/10)	2) Ashuganj-1(09/11/10)	8) Shahjibazar #5 & 6(21/7/11)
3) Kaptai #3 (1/12/10)	3) Raozan-2 (26/03/11)	9) Khulna 60 MW (10/9/11)
	4) WMPL #2(1/8/11)	10) Barapukuria-2(1/11/11)
	5) Bhola RPP (18/7/11)	11) Raozan-1 (27/10/11)
	6) Siddhirganj ST 210 MW (1/	8/11)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

) Due to low gas pressure HPL 360 MW, Siddhirganj 210 MW(PP), Sikalbaha 150 MW and Tongi 105 MW were limited to 222 MW, 44 MW, 100 MW and 35 MW respectively.) After maintenance Ghorasal #3 was synchronized at 17:15.) Ashuganj #4 was shut down at 13:41 and was synchronized at 20:38.) Barapukuria #2 was shut down at 23:40 due to tube leakage maintenance. Tangail-Kabirpur 132 kV ckt-2 was under shut down from 08:35 to 15:35 due to annual maint.) Bogra-Siraiganj 230 kV ckt-2 was under shut down from 08:35 to 15:35 due to annual maint.) Baroulia-AKSPL 132 kV ckt was shut down at 09:27 due to maintenance of equipments & bus at AKSPL. Faridpur-MadAripur 132 kV vkt-1 was shut down at 10:20 due to red hot maintenance was switched on at 12:21. Hathazari-Comilla 230 kV ckt-2 tripped at 11:55 showing differential E/F relay and was	
Tongi 105 MW were limited to 222 MW, 44 MW, 100 MW and 35 MW respectively. After maintenance Ghorasal #3 was synchronized at 17:15. Ashuganj #4 was shut down at 13:41 and was synchronized at 20:38. Barapukuria #2 was shut down at 23:40 due to tube leakage maintenance. Tangail-Kabirpur 132 kV ckt-2 was under shut down from 08:20 to 17:14 due to annual maint. Bogra-Sirajganj 230 kV ckt-2 was under shut down from 08:35 to 15:35 due to annual maint. Baroulia-AKSPL 132 kV ckt was shut down at 09:27 due to maintenance of equipments but at AKSPL. Faridpur-Madaripur 132 kV vkt-1 was shut down at 10:20 due to red hot maintenance was switched on at 12:21. Hathazari-Comilla 230 kV ckt-2 tripped at 11:55 showing differential E/F relay and was	(21:00) of load shed was imposed over the
) After maintenance Ghorasal #3 was synchronized at 17:15.) Ashuganj #4 was shut down at 13:41 and was synchronized at 20:38.) Barapukuria #2 was shut down at 23:40 due to tube leakage maintenance. Tangail-Kabirpur 132 kV ckt-2 was under shut down from 08:20 to 17:14 due to annual maint.) Bogra-Sirajganj 230 kV ckt-2 was under shut down from 08:35 to 15:35 due to annual maint.) Baroulia-AKSPL 132 kV ckt was shut down at 09:27 due to maintenance of equipments & bus at AKSPL. Faridpur-Madaripur 132 kV vkt-1 was shut down at 10:20 due to red hot maintenance was switched on at 12:21. Hathazari-Comilla 230 kV ckt-2 tripped at 11:55 showing differential E/F relay and was	e national grid .
) Ashuganj #4 was shut down at 13:41 and was synchronized at 20:38.) Barapukuria #2 was shut down at 23:40 due to tube leakage maintenance. Tangail-Kabirpur 132 kV ckt-2 was under shut down from 08:20 to 17:14 due to annual maint.) Bogra-Sirajganj 230 kV ckt-2 was under shut down from 08:35 to 15:35 due to annual maint.) Baroulia-AKSPL 132 kV ckt was shut down at 09:27 due to maintenance of equipments & bus at AKSPL. Faridpur-Madaripur 132 kV vkt-1 was shut down at 10:20 due to red hot maintenance was switched on at 12:21. Hathazari-Comilla 230 kV ckt-2 tripped at 11:55 showing differential E/F relay and was	
) Barapukuria #2 was shut down at 23:40 due to tube leakage maintenance. Tangail-Kabirpur 132 kV ckt-2 was under shut down from 08:20 to 17:14 due to annual maint.) Bogra-Sirajganj 230 kV ckt-2 was under shut down from 08:35 to 15:35 due to annual maint.) Baroulia-AKSPL 132 kV ckt was shut down at 09:27 due to maintenance of equipments & bus at AKSPL. Faridpur-Madaripur 132 kV vkt-1 was shut down at 10:20 due to red hot maintenance was switched on at 12:21. Hathazari-Comilla 230 kV ckt-2 tripped at 11:55 showing differential E/F relay and was	
Tangail-Kabirpur 132 kV ckt-2 was under shut down from 08:20 to 17:14 due to annual maint.) Bogra-Sirajganj 230 kV ckt-2 was under shut down from 08:35 to 15:35 due to annual maint.) Baroulia-AKSPL 132 kV ckt was shut down at 09:27 due to maintenance of equipments & bus at AKSPL. Faridpur-Madaripur 132 kV vkt-1 was shut down at 10:20 due to red hot maintenance was switched on at 12:21. Hathazari-Comilla 230 kV ckt-2 tripped at 11:55 showing differential E/F relay and was	
) Bogra-Sirajganj 230 kV ckt-2 was under shut down from 08:35 to 15:35 due to annual maint.) Baroulia-AKSPL 132 kV ckt was shut down at 09:27 due to maintenance of equipments & bus at AKSPL. Faridpur-Madaripur 132 kV vkt-1 was shut down at 10:20 due to red hot maintenance was switched on at 12:21. Hathazari-Comilla 230 kV ckt-2 tripped at 11:55 showing differential E/F relay and was	
) Baroulia-AKSPL 132 kV ckt was shut down at 09:27 due to maintenance of equipments & bus at AKSPL. Faridpur-Madaripur 132 kV vkt-1 was shut down at 10:20 due to red hot maintenance was switched on at 12:21. Hathazari-Comilla 230 kV ckt-2 tripped at 11:55 showing differential E/F relay and was	
& bus at AKSPL. Faridpur-Madaripur 132 kV vkt-1 was shut down at 10:20 due to red hot maintenance was switched on at 12:21. Hathazari-Comilla 230 kV ckt-2 tripped at 11:55 showing differential E/F relay and was	
Faridpur-Madaripur 132 kV vkt-1 was shut down at 10:20 due to red hot maintenance was switched on at 12:21. Hathazari-Comilla 230 kV ckt-2 tripped at 11:55 showing differential E/F relay and was	
was switched on at 12:21. Hathazari-Comilla 230 kV ckt-2 tripped at 11:55 showing differential E/F relay and was	
switched on at 12:29.	
) Siddirganj PP unit Tr-2 transformer was shut down at 10:01 due to oil leakage maintenance and was switched on at 12:36.	
Khulna KPCL-2 was shut down at 09:28 due to emergency maintenance and was synchronized at 12:54.	

Deputy / Asstt. Manager Network Operation Division Manager

Network Operation Division

Deputy General Manager Load Despatch Circle