

**POWER GRID COMPANY OF BANGLADESH LTD.**  
**NATIONAL LOAD DESPATCH CENTER**  
**DAILY REPORT**

QF-LDC-08  
Page -1

Till now the maximum generation is :-		5243.5 MW	at 22:00	Hrs	Reporting Date : 26-Nov-11
The Summary of Yesterday's (		25-Nov-11	) Generation & Demand		on 29-Aug-11
Day Peak Generation :		3176.0	MW	Hour :	12:00
Evening Peak Generation :		4844.0	MW	Hour :	18:00
E.P. Demand (at gen end) :		4844.0	MW	Hour :	18:00
Maximum Generation :		4844.0	MW	Hour :	18:00
Total Gen. (MKWH) :		81.62	System L/ Factor :	85.41%	
<b>EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR</b>					
Export from East grid to West grid :- Maximum		430	MW	at 8:00	Energy 7.709 MKWHR.
Import from West grid to East grid :- Maximum		-	MW	at -	Energy - MKWHR.
Water Level of Kaptai Lake at 6:00 A M on 26-Nov-11					
Actual :	101.65	Ft.(MSL) ,	Rule curve :	106.50	Ft.( MSL )
Gas Consumed : Total		653.29	MMCFD.	Oil Consumed (PDB) :	
				HSD :	Liter
				FO :	Liter
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :	Tk52,167,813		
		Coal :	Tk9,475,930	Oil :	Tk51,880,508
				Total :	Tk113,524,251

**Load Shedding & Other Information**

Area	Yesterday		Today		
	MW		Estimated Demand(s/s end) from 10:00	Estimated Shedding (s/s end) MW	Rates of Shedding (On Estimated Demand)
Dhaka	-	0	1858	-	-
Chittagong Area	-	0	483	-	-
Khulna Area	-	0	544	-	-
Rajshahi Area	-	0	490	-	-
Comilla Area	-	0	360	-	-
Mymensing Area	-	0	267	-	-
Sylhet Area	-	0	278	-	-
Barisal Area	-	0	86	-	-
Rangpur Area	-	0	274	-	-
<b>Total</b>	<b>0</b>		<b>4640</b>	<b>0</b>	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal 6(18/07/10)
2) Ghorasal 2(26/04/10)	2) Ashuganj-1(09/11/10)
3) Kaptai #3 (1/12/10)	3) Raozan-2 (26/03/11)
4) Siddhirganj GT-1(21/11/11)	4) WMPL #2(1/8/11)
5) Siddhirganj GT-2(22/11/11)	5) Bhola RPP (18/7/11)
	6) Siddhirganj ST 210 MW (1/8/11)
	7) Sikalbaha GT 150MW (14/11/11)
	8) Shahjibazar #5 & 6(21/7/11)
	9) Sylhet-20MW(16/11/11)
	10) Ashuganj-3(10/11/11)
	11) Khulna-110 MW(7/11/11)
	12) Sikalbaha 60 MW(16/11/11)
	13) Ashuganj GT1 & ST(10/11/11)

**Additional Information of Machines. lines. Interruption / Forced Load shed etc.**

Description	Forced load shaded / Interrupted Areas
a) Due to annual maintenance the following 132/33 kV transformers were under shut down: Srimongal T2 from 08:55 to 10:36, Saidpur T3 from 09:10 to 15:10, Mymensingh T3 from 08:03 to 14:12, Kishoreganj T3 from 08:17 to 16:01.	Power interruption occurred (about 10 MW) under Rajshahi S/S areas from 10:12 to 10:55.
b) Due to annual maintenance the following 132kV lines was under shut down : Hasnabad-Sitalakhya Ckt from 08:55 to 10:36, Siddhirganj-Haripur Ckt-1 from 09:37 to 16:16.	
c) Rajshahi 132/33 kV T3 transformer was under shut down from 10:12 to 10:55 due to red hot maintenance.	

Deputy / Asstt. Manager  
Network Operation Division

Manager  
Network Operation Division

Deputy General Manager  
Load Despatch Circle