

QF-LDC-08
Page -1

Reporting Date : 2-Mar-12
on 29-Aug-11

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Actual :		83.57	Ft.(MSL) ,	Rule curve :	92.84	Ft.(MSL)
----------	--	-------	------------	--------------	-------	------------

Cost of the Consumed Fuel (PDB+Pvt) :	Gas :	Tk57,272,080		
	Coal :	Tk5,330,210	Oil : Tk183,273,545	Total : Tk245,875,835

Area	Yesterday		Today		
	MW		Estimated Demand(s/s end) from to MW	Estimated Shedding (s/s end) MW	Rates of Shedding (On Estimated Demand)
Dhaka	140	18:10-02:58	1855	94	5%
Chittagong Area	94	18:10-02:20	552	45	8%
Khulna Area	91	18:10-02:08	570	44	8%
Rajshahi Area	81	18:10-01:07	530	44	8%
Comilla Area	40	18:10-02:58	366	29	8%
Mymensing Area	30	18:10-01:30	305	25	8%
Sylhet Area	23	18:10-00:20	266	15	6%
Barisal Area	7	18:10-02:08	112	7	6%
Rangpur Area	42	18:10-01:03	302	24	8%
Total	548	21:00	4858	327	

	Planned Shut- Down	Forced Shut- Down
	1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal 6(18/07/10) 09) Ashuganj-3(10/11/11)
	2) Ghorasal 2(26/04/10)	2) Ashuganj-1(09/11/10) 10) Khulna-110 MW(7/11/11)
	3) Kaptai #3 (1/12/10)	3) Raosan-2 (26/03/11) 11) Sikalbaha 60 MW(16/11/11)
		4) WMPL #2(1/8/11) 12) Raosan-1 (24/11/11)
		5) Bhola RPP (18/7/11) 13) Khulna-60 MW(24/1/12)
		6) Siddhirganj ST 210 MW (1/8/11) 14) Haripur SBU GT-2 (17/02/12)
		7) Sikalbaha GT 150MW (14/11/11) 15) Ghorasal-3(1/3/12)
		8) Shahibazar #5 & 6(21/7/11) 16) B.Pukuria #1(29/2/12)

Description		Forced load shaded / Interrupted Areas
<p>a) There was generation shortage in the evening peak hour yesterday.</p> <p>b) Due to low gas pressure HPL 360 MW, Siddhirganj 210 MW , Megnaghat 450 MW and Tongi 105 MW were limited to 226 MW, 44 MW, 400 MW and 50 MW respectively.</p> <p>c) Mirpur-Aminbazar 132kV Ckt-1 was under shut down from 08:25 to 15:21 due to annual maint.</p> <p>d) After maintenance Baghabari 71 MW was synchronized at 15:19.</p> <p>e) After maintenance Ghorasal #5 was synchronized at 18:12.</p> <p>f) Ghorasal #3 was forced shut down at 23:22 due to super heater water tube leakage.</p> <p>g) Tongi GT was shut down at 06:29(2/3/12) due to filter cleaning.</p>	<p>So about 548 MW (21:00) of load shed was imposed over the whole areas of the national grid .</p>	
		<p>Due to generation shortage, about 625 MW (09:00) of load shed has been running since morning (02/03/12) over the whole area (except Sylhet) of the national grid.</p>

Deputy / Asstt. Manager
Network Operation Division

Manager
Network Operation Division

Deputy General Manager
Load Despatch Circle