

QF-LDC-08
Page -1

Reporting Date : 11-Mar-12
Hrs on 29-Aug-11

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

| | | | | | | |
|----------|--|-------|------------|--------------|-------|------------|
| Actual : | | 80.80 | Ft.(MSL) , | Rule curve : | 91.41 | Ft.(MSL) |
|----------|--|-------|------------|--------------|-------|------------|

| | | | | | |
|---------------------------------------|--------|--------------|-------|---------------|-----------------------|
| Cost of the Consumed Fuel (PDB+Pvt) : | Gas : | Tk58,148,877 | | | |
| | Coal : | Tk5,414,819 | Oil : | Tk209,183,513 | Total : Tk272,747,209 |

| Area | Yesterday | | Today | | |
|-----------------|------------|--------------|---|------------------------------------|--|
| | MW | | Estimated Demand(s/s end) from to MW | Estimated Shedding (s/s end) MW | Rates of Shedding (On Estimated Demand) |
| Dhaka | 90 | 18:10-03:49 | 1982 | 134 | 7% |
| Chittagong Area | 60 | 18:10-03:050 | 565 | 51 | 9% |
| Khulna Area | 63 | 18:10-03:04 | 545 | 50 | 9% |
| Rajshahi Area | 61 | 18:10-01:30 | 600 | 56 | 9% |
| Comilla Area | 49 | 18:10-03:05 | 390 | 36 | 9% |
| Mymensing Area | 39 | 18:10-03:49 | 320 | 30 | 9% |
| Sylhet Area | - | 0 | 280 | 22 | 8% |
| Barisal Area | 12 | 18:10-03:04 | 119 | 10 | 8% |
| Rangpur Area | 33 | 18:10-01:30 | 330 | 31 | 9% |
| Total | 407 | 20:00 | 5131 | 420 | |

| | Planned Shut- Down | Forced Shut- Down |
|--|--------------------------------|---|
| | 1) Haripur SBU GT-3 (18/06/09) | 1) Ghorasal 6(18/07/10) 09) Ashuganj-3(10/11/11) |
| | 2) Ghorasal 2(26/04/10) | 2) Ashuganj-1(09/11/10) 10) Khulna-110 MW(7/11/11) |
| | 3) Kaptai #3 (1/12/10) | 3) Raozan-2 (26/03/11) 11) Sikalbaha 60 MW(16/11/11) |
| | | 4) WMPL #2(1/8/11) 12) Raozan-1 (24/11/11) |
| | | 5) Bhola RPP (18/7/11) 13) Khulna-60 MW(24/1/12) |
| | | 6) Siddhirganj ST 210 MW (1/8/11) 14) Baghabari-71 MW(6/3/12) |
| | | 7) Sikalbaha GT 150MW (14/11/11) |
| | | 8) Shahibbazar #5 & 6(21/7/11) |

| Description | Forced load shaded / Interrupted Areas |
|---|---|
| a) There was generation shortage in the evening peak hour yesterday. | So about 407 MW (20:00) of load shed was imposed over the whole(Except Sylhet) areas of the national grid . |
| b) Due to low gas pressure HPL 360 MW, Siddhirganj 210 MW , Megnaghat 450 MW and Tongi 105 MW were limited to 285 MW, 45 MW, 442 MW and 60 MW respectively. | |
| c) Ashuganj-Comilla(N) 230kV Ckt-1 was under shut down from 08:08 to 19:54 due to A/M. | |
| d) Kulshi-Bakulia 132 kV Ckt-2 was under shut down from 08:20 to 15:02 due to A/M. | |
| e) Tongi 132kV bus-2 was under shut down from 09:06 to 14:20 due to annual maintenance. | |
| f) Mirpur 132/33kV T2 transformer tripped at 15:25 due to 33kV Kafur feeder trip and was switched on at 16:01. | |
| g) After maintenance Shahjibazar-Ashuganj 132 kV line was switched on at 02:20(11/3/12). | |
| h) After maintenance B.Pukuria #1 was synchronized at 00:22(11/3/12). | |
| i) Comilla(N) 132 kV bus tripped at 07:25(11/3/12) due to LT CB bushing burst showing busbar protection relay and was switched on at 08:46. | |
| j) Ullon-Rampura 132kV cable Ckt-1 tripped at 07:45(11/3/12) form Rampura end showing dist.Z1 relay and was switched on at 08:04. | |
| k) Ullon-Dhanmondi 132kV Ckt-3 tripped at 07:45(11/3/12) showing diff.B-phase relay and is now under maintenance. | |
| | Due to generation shortage, about 496 MW (09:00) of load shed has been running since morning (11/03/12) over the whole area (except Sylhet) of the national grid. |

Deputy / Asstt. Manager
Network Operation Division

Manager
Network Operation Division

Deputy General Manager
[Load Despatch Circle](#)