

QF-LDC-08
Page -1

Reporting Date : 18-Aug-10
on 16-Aug-10

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Cost of the Consumed Fuel (PDB) :	Gas	:	Tk58,640,933		Oil	:	Tk66,764,082	Total	:	Tk125,405,015
-----------------------------------	-----	---	--------------	--	-----	---	--------------	-------	---	---------------

Area	Yesterday		Today		
			Estimated Demand(s/s end) from 10:00 MW	Estimated Shedding (s/s end) from 10:00 MW	Rates of Shedding (On Estimated Demand)
	MW				
Dhaka	463	(18:20-0:55 gen. shortage)	2044	404	20%
Chittagong Area	140	(18:20-05:20 gen. shortage)	583	143	25%
Khulna Area	133	(18:20-05:25 gen. shortage)	532	131	25%
Rajshahi Area	105	(18:20-05:25 gen. shortage)	438	108	25%
Comilla Area	80	(18:20-05:02 gen. shortage)	345	85	25%
Mymensing Area	57	(18:20-04:50 gen. shortage)	228	57	25%
Sylhet Area	25	(18:20-23:10 gen. shortage)	229	20	9%
Barisal Area	17	(18:20-05:25 gen. shortage)	104	26	25%
Rangpur Area	54	(18:20-05:25 gen. shortage)	245	61	25%
Total	1074	20:00	4748	1035	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
	1) Kaptai- 3 (19/04/08)
	2) Khulna 110MW (31/03/09)
	3) Haripur SBU GT-3 (18/06/09)
	4) Ghorasal 2(26/04/10)
	5) Siddirganj GT-1 (18/06/10)
	6) Ghorasal 6(18/07/10)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 1074 MW (20:00) of load shed was imposed over the whole areas of the national grid .
b) Due to gas limitation,RPCL (210 MW) ,Tongi(105 MW) ,HPL (360 MW) and Baghabari(71MW) Baghabari(100MW) were limited to 106 MW,350 MW,55 MW and 49 MW respectively.	
c) After maintenance Ashuganj CCPP St was synchronized at 14:13.	Power interruption (2 MW) occurred under Noapara S/S areas from 11:05 to 13:02.
d) After maintenance Siddirganj GT-2 was synchronized at 23:11.	
e) Ashuganj #3 was forced shut down at 12:30 due to Reheater spray line leakage .	
f) Ghorasal new RPP (100 MW) was synchronized to the system(On test) at 20:20.	
g) Ghorasal - Ghorasal new RPP 132 KV (New line) line was switched on at 18:20.	
h) Hasnabad 132/33 KV T6 X-former was shut down at 10:50 due to red hot maintenance and was switched on at 12:30.	Power interruption (26 MW) occurred under Coxbazar S/S areas from 06:58(18/8/10) to 07:00(18/8/10).
i) Noapara 132/33 KV T2 X-former was shut down at 11:05 due to oil leakage maintenance and was switched on at 13:02.	
j) Coxbazar 33 KV & 132 KV bus was shut down at 06:58(18/8/10) & 07:00(18/8/10) due to schedule maintenance work.	

Deputy General Manager
Load Despatch Circle