POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

QF-LDC-08 Page -1

Reporting Date 1-Sep-12 Till now the maximum generation is: **6350 MWW** at 4-Aug-12 The Summary of Yesterday's (31-Aug-12) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 4517.0 MW Hour 12:00 Min. Gen. at 7:00 4503 MW Evening Peak Generation 5805.0 MW 6360 MW Hour : 20:00 Max Generation E.P. Demand (at gen end) : MW Max Demand 6150 MW Hour 20:00 Maximum Generation 5805.0 MW Hour : 20:00 Shortage -210 MW Total Gen. (MKWH) 117.65 System L/ Factor 93.38% Load Shed 0 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR MW MKWHR. Export from East grid to West grid :- Maximum 810 at 21:00 Energy 17.263 Import from West grid to East grid :- Maximum MKWHR. MW at Energy Water Level of Kaptai Lake at 6:00 A M on 1-Sep-12 Actual: 102.67 Ft.(MSL) 99.00 Ft.(MSL) Rule curve : Oil Consumed (PDB) : Gas Consumed: Total 922.53 MMCFD. HSD : Liter FO: Liter Tk73,667,701 Cost of the Consumed Fuel (PDB+Pvt) : Gas Tk18,907,486

Load Shedding & Other Information

Area	Yesterday		Today			
			Estimated Demand(s/s end)	Estimated Shedding (s/s er	Estimated Shedding (s/s en Rates of Shedding	
	MW		from toMW	MW	(On Estimated Demand)	
Dhaka	-	0	2303	-	-	
Chittagong Area	-	0	611	-	-	
Khulna Area		0	671	-	-	
Rajshahi Area		0	597	-	-	
Comilla Area		0	414	-	-	
Mymensing Area		0	326	-	-	
Sylhet Area		0	310	-	-	
Barisal Area		0	129	-	-	
Rangpur Area	-	0	338	-	-	
Total	0		5699	0		

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down	
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal 6(18/07/10)	9) Sikalbaha-150 MW(24/8/12)
2) Ghorasal 2(26/04/10)	2) Ashuganj-1(09/11/10)	
3) Kaptai #3 (1/12/10)	3) Khulna-60 MW(24/1/12)	
4) Sikalbaha-60 MW(2/7/12)	4) Shahjibazar #5 & 6(21/7/11)	
	5) Ashuganj CC ST(3/6/12)	
	6) Khulna-110 MW(21/6/12)	
	7) WMPL #1(1/5/12)	
	8) Raozan #2 (8/8/12)	

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description Forced load shaded / Interrupted Areas

- a) Ghorasal-Bhulta 132kV line tripped at 12:10 from Ghorasal end showing remote protection C-phase and was switched on at 12:25.
- b) Ghorasal 45MW tripped at 12:10 due to back feed failure and was synchronized at 12:40.
- c) Comilla Ckt-1 shifted from bus-2 to bus-1 in Ashuganj S/S (230 kV) for protection work of Comilla Ckt-2.
- d) Ashuganj-Comilla 230kV Ckt-1 was under shut down from 10:27 to 13:59 for protection work at Ashuganj end.
- e) Haripur 132kV bus section-1 was under shut down from 12:40 to 14:05 due to EGCB project work.
- f) Haripur 230/132kV Tr-3 was under shut down from 15:05 to 16:10 due to red hot maintenance at Y-phase bus.
- g) Fenchuganj-Bibiana 230kV Ckt-2 was switched on at 15:53.
- h) Ashuganj #2 tripped at 02:08(1/9/12) due to burner problem
- i) Naogaon-Joypurhat 132kV line was under shut down at 07:30(1/9/12) due to line rearrangement.

Deputy / Asstt. Manager Network Operation Division Manager

Network Operation Division

Deputy General Manager Load Despatch Circle