

QF-LDC-08  
Page -1

Reporting Date : 3-Sep-12  
on 4-Aug-12

### EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

MKWHR.

3-Sep-12

Ft.( MSL )

Oil Consumed (PDB) :

Liter

Liter

Total : Tk438,395,603

Area	Yesterday		Today		
	MW		Estimated Demand(s/s end) from to MW	Estimated Shedding (s/s end) MW	Rates of Shedding (On Estimated Demand)
Dhaka	107	18:30-00:25	2354	152	6%
Chittagong Area	56	18:30-00:25	665	74	11%
Khulna Area	32	18:30-00:25	730	82	11%
Rajshahi Area	35	18:30-00:25	670	73	11%
Cornilla Area	32	18:30-00:25	460	50	11%
Mymensing Area	14	18:30-00:25	355	39	11%
Sylhet Area	-	0	302	-	-
Barisal Area	14	18:30-00:25	140	15	11%
Rangpur Area	18	18:30-00:25	370	42	11%
<b>Total</b>	<b>308</b>	<b>19:30</b>	<b>6046</b>	<b>527</b>	

Information of the Generating machines under shut down.

	Planned Shut-Down	Forced Shut-Down
	1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal 6 (18/07/10)
	2) Ghorasal 2(26/04/10)	9) Sikalbaha-150 MW(24/8/12)
	3) Kaptai #3 (1/12/10)	2) Ashuganj-1(09/11/10)
	4) Sikalbaha-60 MW(27/7/12)	3) Khuina-60 MW(24/1/12)
		4) Shahjibazar #5 & 6(21/7/11)
		5) Ashuganj CC ST(3/6/12)
		6) Khuina-110 MW(21/6/12)
		7) WMPL #1(1/5/12)
		8) Raozan #2 (8/8/12)

**Additional Information of Machines, lines, Interruption / Forced Load shed etc.**

Description	Forced load shaded / Interrupted Areas
<p>a) There was generation shortage in the evening peak hour yesterday.</p> <p>b) Due to low gas pressure HPL 360 MW, Tongi 105 MW and Raozan 360 MW were limited to 321 MW, 45 MW and 100 MW respectively.</p> <p>c) Kabirpur 132/33kV T3 transformer tripped at 10:15 showing O/C relay and was switched on at 10:22.</p> <p>d) Haripur 230/132 kV Tr-1 is under shut down since 10:45 for 20days due to transformer replacement</p> <p>e) Ashuganj-Serajganj 230kV Ckt-1 was under shut down from 09:10 to 12:41 due to busbar protection relay installation work.</p> <p>f) Ghorasal-Ashuganj 230kV Ckt-2 was under shut down from 12:48 to 14:55 due to busbar relay installation work.</p> <p>g) Mymensingh-Kishoreganj 132kV Ckt-1 &amp; 2 tripped at 06:28(3/9/12) from Mymensingh end showing E/F at Ckt-1 &amp; auxiliary trip relay at Ckt-2 and was switched on at 07:17,07:12. At the same time Mymensingh-Netrokona Ckt-1 also tripped from Mymensingh end sowing dist.ABC, O/C relays and was switched on at 07:17(3/9/12).</p> <p>h) Ashuganj 230/132kV OAT11 was under shut down from 07:48 to 10:24(3/9/12) due to protection work.</p> <p>k) Occurrence report of 02 September-2012 is attached herewith.</p>	<p>So about 308 MW (19:30) of load shed was imposed over the whole areas(except Sylhet) of the national grid .</p> <p>Power interruption occurred (about 108 MW) under Mymensingh, Jamalpur &amp; Netrokona S/S areas from 06:28 to 07:12(3/9/12).</p> <p>Due to generation shortage, about 331 MW (09:00) of load shed has been running since morning (03/09/12) over the whole area (except Sylhet) of the national grid.</p>
Deputy / Asstt. Manager Network Operation Division	Deputy General Manager Load Despatch Circle
Manager Network Operation Division	