

QF-LDC-08
Page -1

Reporting Date : 12-Sep-12
on 4-Aug-12

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

12-Sep-12

Et (MSI) Y

Oil Consumed (PDB) :

Liter

Liter

k376,723,973

Area	Yesterday		Today		
	MW		Estimated Demand(s/s end) from 10MW	Estimated Shedding (s/s end) MW	Rates of Shedding (On Estimated Demand)
Dhaka	200	(09:30-02:10)	2200	133	6%
Chittagong Area	90	(09:30-02:10)	625	77	12%
Khulna Area	65	(09:30-02:10)	660	81	12%
Rajshahi Area	56	(09:30-02:10)	630	78	12%
Comilla Area	49	(09:30-02:10)	435	54	12%
Mymensing Area	28	(09:30-02:10)	345	41	12%
Sylhet Area	-	0:00	284	-	-
Barisal Area	20	(09:30-02:10)	130	12	9%
Rangpur Area	35	(09:30-02:10)	345	40	12%
Total	543	20:00	5654	516	

Information of the Generating machines under shut down.

	Planned Shut- Down	Forced Shut- Down
	1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal 6(18/07/10) 9) Raozan #1(8/9/12)
	2) Ghorasal 2(26/04/10)	2) Ashuganj-1(09/11/10)
	3) Kaptai #3 (1/12/10)	3) Khulna-60 MW(24/1/12)
	4) Sikalabaha-60 MW(27/12)	4) Shahjibazar #5 & 6(21/7/11)
		5) Ashuganj CC ST(3/6/12)
		6) Khulna-110 MW(21/6/12)
		7) WMPL #1(1/5/12)
		8) Raozan #2 (8/8/12)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shed / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 543 MW (20:00) of load shed was imposed over the whole(except Sylhet) areas of the national grid .
b) Comilla-Hathazari 132 kV Ckt-1 was shut down at 10:05 due to project work and was switched on at 17:05.	
c) Mymensing-Netrokona 132 kV Ckt-2 & 1 were shut down at 10:35 & 14:54 due to protection work and were switched on at 14:11 & 16:31 respectively.	Power interruption occurred (about 40 MW) under Bhulta S/S area from 15:03 to 16:06.
d) Jhenida-Bottail 132 kV Ckt-2 was shut down at 12:05 due to protection test and were switched on at 19:40.	
e) Natore-Rajshahi 132 kV Ckt was shut down at 12:24 due to Ammeter change and was switched on at 12:40.	
f) Kabirpur 132/33 kV T3 transformer tripped at 14:57 showing O/C relay and was switched on at 15:00.	
g) Bhulta 132/33 kV T1 transformer was shut down at 15:03 due 132kV PT maintenance & CT fuse replacement and was switched on at 16:06.	
h) Faridpur-Bheramara 132 kV Ckt-1 & 2 tripped at 20:58 showing O/C relay and were switched on at 21:03.	

Deputy General Manager
Load Despatch Circle