POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER. LDC.DHAKA DAILY REPORT ontin

QF-LDC-08 Page -1

			DAILT	REFURI				Page - I
					Report	ting Date :	2-Jul-10	
Till now the maximum generation	i is : -	4606.0 MW at		22:00	Hrs on 2	14-Apr-10		
The Summary of Yesterday's (1-Jul-10) Generation & Demand			Today's Actual M	lin Gen. & Pr	obable Gen. a	& Demand
Day Peak Generation :	3768.0	MW Hour :		9:00	Min Gen. at	8:00	3676	MW
Evening Peak Generation :	3922.5	MW Hour :		21:00	Max Generation	:	4030	MW
E.P. Demand (at gen end) :	5000.0	MW Hour :		21:00	Max Demand	:	4800	MW
Maximum Generation :	3966.5	MW Hour :		24:00	Shortage	:	770	MW
Total Gen. (MKWH) :	88.65	System L/ Factor :		85.41%	Load Shed	:	651	MW
	EXPOR	T/IMPORT THROUGH EAST	-WEST INTE	ERCONNECTOR				
Export from East grid to West grid :-	- Maximum	430		MW at	1:00	Energy	8883000	KWHR.
Import from West grid to East grid :-	- Maximum	-		MW at	-	Energy	-	KWHR.
	Water Level of Kaptai Lak	e at 6:00 A M of		2-Jul-10				
Actual : 95.19	Ft.(MSL),		Rule cur	ve: 86.96	Ft.(MSL)			
Gas Consumed : Total	797.92	MMCFt.		Oil Consume	ed (PDB):			
					i i i	HSD :	1825376	Liter
					F	=O :	0	Liter

Cost of the Consumed Fuel (PDB): Gas :

Tk58,974,267

Load Shedding & Other Information

Area	Yesterday		Today			
			Estimated Demand(s/s end)	Estimated Shedding (s/s e	Rates of Shedding	
	MW		from toMW	MW	(On Estimated Demand)	
Dhaka	371	(18:30-06:00, gen. shortage)	1762	268	15%	
Chittagong Area	117	(18:30-05:55, gen. shortage)	507	93	18%	
Khulna Area	130	(18:30-05:20, gen. shortage)	445	81	18%	
Rajshahi Area	95	(18:30-05:44, gen. shortage)	370	68	18%	
Comilla Area	77	(18:30-05:45, gen. shortage)	288	52	18%	
Mymensing Area	51	(18:30-05:50, gen. shortage)	215	39	18%	
Sylhet Area	-	0	187	-	-	
Barisal Area	13	(18:30-05:20, gen. shortage)	88	15	17%	
Rangpur Area	57	(18:30-05:44, gen. shortage)	198	35	18%	
Total	911	21:00	4060	651		

Information of the Generating machines under shut down.

Planned Shut- Down		Forced Shut- Down
	1) Kaptai- 3 (19/04/08)	8) Siddhirganj GT-1 (16/06/10)
	2) Khulna 110MW (31/03/09)	9) Kaptai -1 (25/06/10)
	3) Haripur SBU GT-3 (18/06/09)	
	4) Ashuganj CCPP ST (05/12/09)	
	5) Raozan -1 (08/05/10)	
	6) Ghorasal 2(26/04/10)	
	7) Kaptai- 4 (17/01/10)	

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description		Forced load shaded / Interrupted Areas		
a) There was generation shortage in the evening peak hour yesterday.		So about 911 MW (21:00) of load shed was imposed over the		
		whole (except Sylhet) areas of the national grid.		
) Due to gas limitation, Raozan (180 MW)	, RPCL (210 MW) and HPL (250 MW)			
were limited to 130 MW, 90 MW and 238	BMW respectively.			
) After maintenance, Siddhirganj GT-1 wa	s synchronized at 12:30 but it tripped at 21:46 due to			
tripping of generator breaker and was sy				
) After maintenance, Khulna 60 MW was s				
	0 (02/07/10) due to condenser tube leakage. er tripped at 09:55 showing ' E/F' and were switched			
	they tripped at 11:05 due to broken of auxiliary			
transformer and were switched on at 12:5				
) Hathazari (Main prot.)- Comilla (N) (DIS	T C & E/F) 230 KV line -1 tripped at 14:20 from both end			
and was switched on at 14:30.				
h) Cox'sbazar 132/33 KV T1 and T2 transformers were under shut down from 14:05 to 15:00 due to maintenance of 33 KV bus PT.		Power interruption occurred (16 MW) under Cox'sbazar S/S areas from 14:05 to 15:00.		
to maintenance of 33 KV bus P1.		areas from 14:05 to 15:00.		
eputy / Asstt. Manager	Manager	Deputy General Manager		
oad Despatch Division	Load Despatch Division	Load Despatch Circle		