POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER. LDC. DHAKA DAILY REPORT

QF-LDC-08 Page -1

Reporting Date: 10-Jul-10 Till now the maximum generation is: 4606.0 MW at 9-Jul-10 The Summary of Yesterday's () Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 3855.0 MW 8:00 Min Gen. at 3857 MW Hour 8:00 Evening Peak Generation 3965.5 MW 19:30 Max Generation 3935 MW E.P. Demand (at gen end) : 4850.0 MW Hour 19:30 Max Demand 5000 MW Maximum Generation 4102 5 MW Hour : 5:00 Shortage 1065 MW Total Gen. (MKWH) 89.90 System L/ Factor 85.41% Load Shed 906 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum MW Energy 10565000 KWHR. Import from West grid to East grid :- Maximum MW at KWHR

Water Level of Kaptai Lake at 6:00 A M of 10-Jul-10
Actual: 96.26 Ft.(MSL), Rule curve: 85.44 Ft.(MSL)

Gas Consumed : Total 817.84 MMCFt. Oil Consumed (PDB) :

HSD : 1816264 Liter

FO: 0 Liter

Cost of the Consumed Fuel (PDB): Gas : Tk60,446,554 Oil : Tk72,650,564 Total : ##########

Load Shedding & Other Information

Area	Yesterday		Today		
			Estimated Demand(s/s end)	Estimated Shedding (s/s e	Rates of Shedding
	MW		from toMW	MW	(On Estimated Demand)
Dhaka	242	(18:30-05:15, gen. shortage)	1810	370	20%
Chittagong Area	157	(18:30-05:00, gen. shortage)	518	119	23%
Khulna Area	103	(18:30-04:50, gen. shortage)	455	105	23%
Rajshahi Area	72	(18:30-05:00, gen. shortage)	378	87	23%
Comilla Area	40	(18:30-05:00, gen. shortage)	293	65	22%
Mymensing Area	57	(18:30-04:50, gen. shortage)	218	48	22%
Sylhet Area	-	0	225	44	20%
Barisal Area	18	(18:30-04:50, gen. shortage)	91	21	23%
Rangpur Area	50	(18:30-05:00, gen. shortage)	204	47	23%
Total	739	19:30	4192	906	

Information of the Generating machines under shut down.

Planned Shut- Down		Forced Shut- Down	
	1) Kaptai- 3 (19/04/08)	7) Siddhirganj GT-1 (16/06/10)	
	2) Khulna 110MW (31/03/09)	8) Kaptai -1 (25/06/10)	
	3) Haripur SBU GT-3 (18/06/09)	9) Ashuagnj -1 (06/07/10)	
	4) Raozan -1 (08/05/10)	10) Sikalbaha (07/07/10)	
	5) Ghorasal 2(26/04/10)		
	6) Kaptai- 4 (17/01/10)		

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 739 MW (19:30) of load shed was imposed over the
	whole (except Sylhet) areas of the national grid .

- b) Due to gas limitation, Raozan (180 MW), RPCL (210 MW), Baghabari GT2 (100 MW), and HPL (250 MW) were limited to 140 MW, 88 MW,60 MW and 239 MW respectively.
- c) Sikalbaha 150 MW was synchronized (on test) at 09:50 and tripped at 16:02.
- d) Ashuganj CCPP St was synchronized at 11:50. It may be synchronized before evening peak hour today.
- e) Madaripur 132/33 KV T1 and T2 transformer tripped at 22:30 due to 33 KV Madaripur feeder fault and were switched on at 23:03.
- f) Thakurgaon 132/33 KV T1 and T2 tripped at 06:34 (10/07/10) showing 'E/F' due to heavy rain and storming and were switched on at 08:55 and 09:20 (10/07/10) respectively.
- g) Thakurgaon -Purbasadipur 132 KV CKT-1 tripped at 07:06 (10/07/10) due to heavy rain & storming and was swiched on at 08:50 (10/07/10).

Power interruption occurred (33 MW) under Madaripur S/S areas from 22:30 to 23:03.

Power interruption occurred (18 MW) under Thakurgaon S/S areas from 06:34 to 08:55.

Deputy / Asstt. Manager Load Despatch Division

Manager Load Despatch Division Deputy General Manager Load Despatch Circle