POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER. LDC.DHAKA DAILY REPORT

Oil Consumed (PDB):

QF-LDC-08 Page -1

Reporting Date: 11-Jul-10 Till now the maximum generation is: 4606.0 MW at 10-Jul-10 The Summary of Yesterday's () Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 3826.0 MW 9:00 Min Gen. at 3840 Hour 7:00 MW Evening Peak Generation 3948.5 MW 19:30 Max Generation 4105 MW E.P. Demand (at gen end) 5000.0 MW Hour 19:30 Max Demand 5100 MW Maximum Generation 4169 5 MW Hour : 4.00 Shortage 995 MW Total Gen. (MKWH) 88.14 System L/ Factor 85.41% Load Shed 633 MW

EXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid: - Maximum 490 MW at 2:00 Energy 9805000 KWHR. Import from West grid to East grid: - Maximum - MW at - Energy - KWHR.

Water Level of Kaptai Lake at 6:00 A M of 11-Jul-10

MMCFt.

Ft.(MSL), Rule curve: 85.60 Ft.(MSL)

HSD : 1843340 Liter

FO : 0 Liter

Cost of the Consumed Fuel (PDB): Gas : Tk60,446,554 Oil : Tk73,733,610 Total : Tk134,180,164

Load Shedding & Other Information

96.35

Actual

Gas Consumed :

Area	Yesterday		Today		
			Estimated Demand(s/s end)	Estimated Shedding (s/s e	Rates of Shedding
	MW		from to/IW	MW	(On Estimated Demand)
Dhaka	398	(18:40-02:11, gen. shortage)	1800	295	16%
Chittagong Area	114	(18:40-02:10, gen. shortage)	490	72	15%
Khulna Area	103	(18:40-02:08, gen. shortage)	433	66	15%
Rajshahi Area	83	(18:40-02:08, gen. shortage)	358	54	15%
Comilla Area	68	(18:40-02:09, gen. shortage)	280	42	15%
Mymensing Area	52	(18:40-02:07, gen. shortage)	210	32	15%
Sylhet Area	-	0	219	31	14%
Barisal Area	20	(18:40-02:08, gen. shortage)	85	12	14%
Rangpur Area	42	(18:40-02:08, gen. shortage)	193	29	15%
Total	880	19:30	4068	633	

Information of the Generating machines under shut down.

Planned Shut- Down		Forced Shut-Down	
	1) Kaptai- 3 (19/04/08)	7) Siddhirganj GT-1 (16/06/10)	
	2) Khulna 110MW (31/03/09)	8) Kaptai -1 (25/06/10)	
	3) Haripur SBU GT-3 (18/06/09)	9) Ashuagnj -1 (06/07/10)	
	4) Raozan -1 (08/05/10)	10) Sikalbaha (07/07/10)	
	5) Ghorasal 2(26/04/10)	11) Ashuganj CCPP ST (05/07/10)	
	6) Kaptai- 4 (17/01/10)		

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 880 MW (19:30) of load shed was imposed over the
	whole (except Sylhet) areas of the national grid.

- b) Due to gas limitation, Raozan (180 MW), RPCL (210 MW), and HPL (250 MW) were limited to 140 MW, 89 MW and 215MW respectively.
- e) Haripur Power Ltd. GT was shut down at 13:47 due to synchronization of Steam turbine. GT and Steam were synchronized at 19:06 and 00:42 (11/07/10) respectively.
- f) Ashuganj Unit -3 tripped at 14:09 due to problem of turbine and was synchronized at 18:24.
- g) Baghabari GT -2 (100 MW) tripped at 16:34 due to exhaust temperature high.
- h) Tongi GT was shut down at 10:48 due to gas pressure low and was synchronized at 00:05 (11/07/10)

Due to generation shortage, about 100 MW (09:00) of load shed has been running since morning (11/07/10) over the whole area (except Sylhet) of the national grid.

Deputy / Asstt. Manager Load Despatch Division

Manager Load Despatch Division Deputy General Manager Load Despatch Circle