POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

QF-LDC-08

Reporting Date : 14-Feb-13 Till now the maximum generation is:-**6350 MWW** at 21:00 4-Aug-12 The Summary of Yesterday's (13-Feb-13) Generation & Demand Today's Actual Min Gen. & Probable Gen. & De Day Peak Generation 4200.0 MW Hour 9:00 Min. Gen. at 4:00 3503 MW Evening Peak Generation 5665.0 MW 5735 19:00 MW Hour : Max Generation E.P. Demand (at gen end) : MW 19:00 5700 MW Hour Maximum Generation 5665.0 MW Hour : 19:00 Shortage -35 MW Total Gen. (MKWH) 101.86 System L/ Factor 83.69% Load Shed 0 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR MW Export from East grid to West grid :- Maximum 720 at 7:00 Energy 14.702 MKWHR. Import from West grid to East grid :- Maximum MKWHR. MW Energy at Water Level of Kaptai Lake at 6:00 A M on 14-Feb-13 Actual: 97.78 Ft.(MSL) Rule curve 95.18 Ft.(MSL) Gas Consumed : Total Oil Consumed (PDB): 843.07 MMCFD. HSD : Liter FO Liter Tk67,322,503 Cost of the Consumed Fuel (PDB+Pvt) : Gas Tk21,642,230 : Tk199,073,551 Total : Tk288,038,284

Load Shedding & Other Information

Area	Yesterday		Today		
			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding
	MW		from toMW	MW	(On Estimated Demand)
Dhaka	-	0:00	1894	-	-
Chittagong Area	-	0:00	568	-	-
Khulna Area	-	0:00	639	-	-
Rajshahi Area	-	0:00	592	-	-
Comilla Area	-	0:00	384	-	-
Mymensing Area	-	0:00	357	-	-
Sylhet Area	-	0:00	266	-	-
Barisal Area	-	0:00	118	-	-
Rangpur Area	-	0:00	354	-	-
Total	0	·	5172	0	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal 6(18/07/10) 8) AES Haripur 360 MW (1/2/13)
2) Ghorasal 2(26/04/10)	2) Ashuganj-1(15/1/13)
3) Raozan #2 (8/8/12)	3) Khulna-60 MW(24/1/12)
	4) Shahjibazar #5 & 6(21/7/11)
	5) Khulna-110 MW(21/6/12)
	6) WMPL #1(1/5/12)
	7) Megnaghat GT-2(13/1/13)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) Madaripur-Gopalganj 132 kV Ckt was under shut down from 08:52 to 08:54 due to A/M. b) Comilla(N)Feni 132 kV Ckt-1 was under shut down from 08:46 to 16:33 due to A/M. c) Hathazari-Raozan 230 kV Ckt-2 was under shut down from 09:07 to 16:14 due to A/M. d) Shahjibazar-B.Baria 132 kV Ckt-2 was under shut down from 09:08 to 15:20 due to A/M. e) Comilla(N) 132 kV main Bus dead operating Busbar protection line tripped at 11:05 and	
was switched on at 11:25. f) Haripur-Norsingdi 132 kV Ckt was under shut down from 10:45 to 17:42 due to maint.work. g) After maintenance Sylhet-150 MW was synchronized at 10:43. h) Ghorasal-45 MW tripped at 10:52 due to auxiliary failure and was synchronized at 11:10. i) Ashuganj #3 tripped at 11:01 due to problem in feed pump void gear and was sync.at 13:39. j) Maniknagar-Bangabhaban 132 kV Ckt was shut down at 08:01 due to cable maintenance at Bangabhaban end and was switched on at 09:59.	

- k) Uttara 132/33 kV T1 transformer was under shut down from 08:46 to 16:40 due to A/M. I) Baghabari-100 MW tripped at 15:11 due to gas control valve problem and was synchronized
- at 08:07(14/2/13).
- m) Baghabari-71 MW was shut down at 07:18(14/2/13) due to filter change and was synchronized at 09:16(14/2/13)...
 n) Shyampur 132/33 kV T2 transformer tripped at 21:53 showing backup protection relay
- and was switched on at 00:15(14/2/13).
- o) Haripur SBU #1 & 2 tripped at 18:48 due to booster problem.

Deputy / Asstt. Manager **Network Operation Division**

Manager Network Operation Division Deputy General Manager Load Despatch Circle