POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

QF-LDC-08 Page -1

Reporting Date : on 4-Aug-12 2-May-13 Till now the maximum generation is:-**6350 MWW** at 21:00 Today's Actual Min Gen. & Probable Gen. & Demand The Summary of Yesterday's (1-May-13) Generation & Demand Day Peak Generation Evening Peak Generation 4647.0 MW Hour 12:00 Min. Gen. at Max Generation 6:00 4808 MW 5982.0 MW 6488 19:30 MW Hour : E.P. Demand (at gen end) : Hour Max Demand 6300 MW Maximum Generation 5982.0 MW Hour : 19:30 Shortage -188 MW 120.16 Total Gen. (MKWH) System L/ Factor 92.97% Load Shed 0 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR MW at 24:00 Export from East grid to West grid :- Maximum 710 Energy MKWHR. 14.641 Import from West grid to East grid :- Maximum MW MKWHR. at Energy Water Level of Kaptai Lake at 6:00 A M on 2-May-13 Actual: 76.08 Ft.(MSL) Rule curve : 81.81 Ft.(MSL) Gas Consumed : Total 994.86 Oil Consumed (PDB): MMCFD. HSD : Liter FO : Liter Cost of the Consumed Fuel (PDB+Pvt) : Tk79,443,540 Gas Tk16,345,379 Oil : Tk256,839,981 Total : Tk352,628,901

Load Shedding & Other Information

Area	Yesterday		Today		
			Estimated Demand(s/s end)	Estimated Shedding (s/s er	Estimated Shedding (s/s en Rates of Shedding
	MW		from toMW	MW	(On Estimated Demand)
Dhaka	-	0:00	2382	-	-
Chittagong Area	-	0:00	612	-	-
Khulna Area	-	0:00	668	-	-
Rajshahi Area	-	0:00	649	-	-
Comilla Area	-	0:00	447	-	-
Mymensing Area	-	0:00	369	-	-
Sylhet Area	-	0:00	301	-	-
Barisal Area	-	0:00	134	-	-
Rangpur Area	-	0:00	378	-	-
Total	0		5940	0	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down	
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal 6(18/07/10)	9) Ashuganj #2(30/4/13)
2) Ghorasal 2(26/04/10)	2) Ashuganj-#1(15/1/13)	
	3) Khulna-60 MW(24/1/12)	
	4) Shahjibazar #5 & 6(21/7/11)	
	5) Khulna-110 MW(21/6/12)	
	6) WMPL #1(1/5/12)	
	7) WMPL #2(24/4/13)	
	8) Sikalbaha-150 MW(29/4/13)	

Additional Information of Mach	1	
Description		Forced load shaded / Interrupted Areas
a) Jhenidah-Bottail 132 kV Ckt-1 was under shut leakage maintenance. b) Madanganj-Bashundhara cement factory 132 kdue to project work.		
c) Purbasadipur 132/33 kV transformer T4 was ur 33 kV Bus.		
d) Meghnaghat GT-1 tripped at 14:10 due to cont		
e) Mymensingh-Jamalpur 132 kV Ckt-1 tripped at		
Mymensingh end and P.T fail dist.C relay at Ja		
f) Sreemongal-Fenchuganj 132 kV Ckt-1 tripped and was switched on at 11:10 (02/05/13). At the Fenchuganj 50 MW RPP and Fenchuganj Bara at 22:26, 22:55 and 23:20 respectively.		
Deputy / Asstt. Manager Network Operation Division	Manager Network Operation Division	Deputy General Manager Load Despatch Circle