

QF-LDC-08 QF-LDC-12
Page -1

Reporting Date : 16-May-13
on 4-Aug-12

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

KWHR

16-May-13

Oil Consumed (PDB) :

Liter

Liter

Total : Tk368

Information of the Generating machines under shut down.

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
<p>a) Saidpur 132/33 kV T4 transformer tripped at 08:40 showing E/F relay at 33 kV side and was switched on at 08:45.</p> <p>c) Bogra 132/33 kV T3 transformer was shut down at 10:04 due to red hot maintenance and was switched on at 11:05.</p> <p>c) Sylhet-50 MW tripped at 12:25 showing fire alarm and was synchronized on at 12:45.</p> <p>d) Tangail 33 kV bus (Partial) was shut down at 16:45 due to red hot maintenance at 33 kV town feeder and was switched on at 17:27.</p>	<p>Power interruption occurred (about 2 MW) under Saidpur S/S areas from 08:40 to 08:45.</p> <p>Power interruption occurred (about 40 MW) under Tangail S/S areas from 16:45 to 17:27.</p>
<p>Deputy / Asstt. Manager Network Operation Division</p>	<p>Manager Network Operation Division</p> <p>Deputy General Manager Load Despatch Circle</p>