POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

QF-LDC-08 Page -1

Reporting Date : 17-Aug-13 Till now the maximum generation is : -6675 MWW at The Summary of Yesterday's (16-Aug-13) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 4216.0 MW Hour 12:00 Min. Gen. at 7:00 3865 MW Evening Peak Generation 5856.0 MW MW Hour: 20:00 Max Generation 6243 E.P. Demand (at gen end) : MW Hour Max Demand MW Maximum Generation 5856.0 MW Hour : 20.00 Shortage -93 MW Total Gen. (MKWH) 108.56 System L/ Factor 81.11% Load Shed 0 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR MW Export from East grid to West grid :- Maximum 630 at 21:00 Energy 13.961 MKWHR. Import from West grid to East grid :- Maximum MW MKWHR. at Energy Water Level of Kaptai Lake at 6:00 A M on 17-Aug-13 94.12 86.22 Ft.(MSL) Ft.(MSL) Actual : Rule curve Gas Consumed : Total 862.85 MMCFD. Oil Consumed (PDB): HSD : Liter FO Liter

Cost of the Consumed Fuel (PDB+Pvt) :

Tk68,902,015 Gas Tk16,057,900

Load Shedding & Other Information

Area	Yesterday		Today		
			Estimated Demand(s/s end)	Estimated Shedding (s/s e	Estimated Shedding (s/s en Rates of Shedding
	MW		from t & IW	MW	(On Estimated Demand)
Dhaka	-	0:00	2325	-	-
Chittagong Area	-	0:00	595	-	-
Khulna Area	-	0:00	650	-	-
Rajshahi Area	-	0:00	632	-	-
Comilla Area	-	0:00	435	-	-
Mymensing Area	-	0:00	361	-	-
Sylhet Area	-	0:00	294	-	-
Barisal Area	-	0:00	131	-	-
Rangpur Area	=	0:00	369	-	-
Total	0		5792	0	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down	
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal 6(18/07/10)	11) Ghorasal-3(8/8/13)
	2) Khulna 110 MW (21/07/13)	12) Fenchuganj #3 (13/08//13)
	3) Khulna-60 MW(24/1/12)	13) Shahjibazar #9 (14/08/13)
	4) Shahjibazar #5 & 6(21/7/11)	14) Chandpur 163 MW (15/08/13)
	6) WMPL #1(1/5/12)	15) Sikalbaha 60 MW (15/08/13)
	7) WMPL #2(24/4/13)	16) Raozan #1 (15/08/13)
	9) Raojan #2 (31/07/13)	
	10) Ashuganj-1(7/8/13)	

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) Haripur EGCB 360 MW synchronized at 09:21 and was shut down at 13:30	

- b) Serajganj 150 MW tripped at 09:56 due to gas line problem and was synchronized at 08:54 (17/08/13)
- c) Kishoreganj 132/33 kV T3 transformer was shut down from 14:32 to 15:40 due to red hot maintenance work.
- d) Neyamatpur 132/33 kV T1 transformer was shut down from 15:10 to 15:50 due to red hot maintenance work.
- e) Bakulia-Modern Steel 132kV Ckt tripped at 17:22 showing Dist. Z1 relay and was switched on at 18:10.
- f) After maintenance B.Baria 70MW was synchronized at 21:09, again tripped at 21:40 and was synchronized at 22;07.
- g) Bus side isolator loop of north west (150 MW) plant torn and touched gantry structure all other running plant in Khulna zone tripped. Due to above fault- 1) North west-166 MW, 2) KPCL1-99 MW, 3) KPCL2-53 MW, 4) Noapara(otobi)-7 MW, 5) Noapara (KhanZahan)-32 MW, 6) Gopalganj-89 MW, total 436 MW Genaration interrupted. At the same time Khulna-Noapara 132 kV Ckt-2 tripped from Khulna end showing phase-A, E/F, Khulna(s)-Khulna© Ckt tripped showing E/F,phase-c relay, Khulna©-Goalpara Ckt-1 tripped showing Dist. Z1, phase-c relay and were switched on at 05:08 & 06:32(17/08/13) respectively
- h) Ishurdi-Bheramara 132 kV Ckt-1& 2 tripped at 04:50 both end showing CAS.CAT.CD,CB41, Dist. prot. CAT relay and was switched on at 05:20, 05:21 (17/08/13) respectively.
- i) Bottail-Bheramara 132kV Ckt-2 tripped at 04:40(17/08/13) both end showing 3 phase ABC relay and was switched on at 05:33.
- j) Sylhet 150 MW tripped at 04:40(17/08/13) due to gas booster tripped and was synchronized at 10:15(17/08/13).

Deputy / Asstt. Manager Network Operation Division Manager

Network Operation Division

Deputy General Manager Load Despatch Circle