POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

QF-LDC-08 Page -1

Reporting Date: 5-Sep-13 Till now the maximum generation is : **6675 MW**WV at 21:00 Hrs on 12-Jul-13 The Summary of Yesterday's (4-Sep-13) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 4867.0 MW Hour: 12:00 Min. Gen. at 7:00 4472 MW Evening Peak Generation 5801.0 MW Hour : 20:00 Max Generation 5951 MW E.P. Demand (at gen end) 6100.0 MW 20:00 Max Demand 6600 MW Maximum Generation 5801.0 MW Hour 20:00 Shortage 649 MW Total Gen. (MKWH) 122.04 System I / Facto 81.11% Load Shed 599 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 540 MW MKWHR. at 5:00 Energy 9.793 Import from West grid to East grid :- Maximum MW Energy MKWHR Water Level of Kaptai Lake at 6:00 A M on 5-Sep-13 91.87 Ft.(MSL) Rule curve : 92.92 Ft.(MSL) Actual Gas Consumed : 869.20 MMCFD. Oil Consumed (PDB): HSD FO Liter Cost of the Consumed Fuel (PDB+Pvt) : Tk69 409 088 Tk10,308,141 : Tk424,264,551 Total : Tk503,981,780

Load Shedding & Other Information

Area	Yesterday		Today		
			Estimated Demand(s/s end)	Estimated Shedding (s/s en	Rates of Shedding
	MW		from toMW	MW	(On Estimated Demand)
Dhaka	83	(18:20-24:00)	2370	161	7%
Chittagong Area	35	(18:20-24:00)	656	94	14%
Khulna Area	35	(18:20-24:00)	710	97	14%
Rajshahi Area	34	(18:20-24:00)	598	-	-
Comilla Area	27	(18:20-24:00)	480	67	14%
Mymensing Area	23	(18:20-24:00)	400	56	14%
Sylhet Area	12	(18:20-24:00)	325	45	14%
Barisal Area	11	(18:20-24:00)	146	21	14%
Rangpur Area	16	(18:20-24:00)	410	58	14%
Total	276	20:00	6095	599	

Information of the Generating machines under shut down.

h) Fenchuganj RPP, Sylhet-50MW, Fenchuganj Prima, Sylhet-10MW tripped at 20:02 due to voltage fluctuation and was synchronized on at 20:30, 20:20, 20:50, 21:03 respectively.

i) Gopalganj 100MW tripped at 21:25 due to voltage fluctuation and was synchronized on at

j) Baghabari 71MW tripped at 02:33(5/9/13) due to fuel system problem and was synchronized

I) Barisal 132/33 kV T1 transformer was shut down from 07:05(5/9/13) to 08:15(5/9/13) due to

m) Faridpur-Madaripur 132kV Ckt-1 was shut down from 07:55(5/9/13) to 10:43(5/9/13) due to

k) Bera peaking tripped at 22:50 due to tripping of outgoing breaker.

red hot maintenance work at Madaripur end.

Planned Shut- Down	Forced Shut- Down	
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal #6(18/07/10)	9) Shahjibazar #9 (14/08/13)
	2) Khulna-60 MW(24/1/12)	10) Ghorasal #2 (21/08/13)
	3) Shahjibazar #5 & 6(21/7/11)	11) Sikalbaha 60 MW (15/08/13)
	4) WMPL #1(1/5/12)	12) Raozan #1 (15/08/13)
	5) WMPL #2(24/4/13)	13) Ghorasal #1(29/08/13)
	6) Raojan #2 (31/07/13)	14) Siddhirganj 100MW(30/08/13)
	7) Ashuganj #1(7/8/13)	
	8) Ghorasal #4 (2/9/13)	

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 276 MW (20:00) of load shed was imposed over the whole areas of the national grid .
b) Hathazari 132/33 kV T2 transformer was shut down from 12:25 to 17:35 due to red hot maintenance work.	Power interruption occurred (about 13 MW) under Hathazari S/S areas from 12:25 to 17:35.
c) Baghabari 100MW tripped at 16:50 due to high exhaust temperature speed.	
d) After maintenance Barapukuria #1 was synchronized on at 18:58.	
e) Norsingdi 132/33 kV transformer was shut down from 19:40 to 19:52 due to smoke over the transformer.	
) Sylhet-Fenchuganj P/S 132 kV Ckt tripped at 20:01 showing distance relay at Fenchuganj P/S end and was switched on at 20:15.	
g) Ghorasal 45MW tripped at 20:35 due to back feed transformer trip and was synchronized on	
at 21:45.	

Deputy / Asstt. Manager Network Operation Division

red hot maintenance work.

00:21(5/9/13).

on at 07:15(5/9/13).

Manager Network Operation Division Deputy General Manager Load Despatch Circle