

QF-LDC-08  
Page -1

Reporting Date : 26-Sep-13  
on 12-Jul-13

### EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Cost of the Consumed Fuel (PDB+Pvt) :	Gas :	Tk69,444,224			
	Coal :	Tk8,665,514	Oil :	Tk419,832,733	Total : Tk497,942,471

Area	Yesterday		Today		
	MW		Estimated Demand(s/s end) from to MW	Estimated Shedding (s/s end) MW	Rates of Shedding (On Estimated Demand)
Dhaka	140	(18:15-03:45)	2340	216	9%
Chittagong Area	69	(18:15-03:45)	630	90	14%
Khulna Area	86	(18:15-03:45)	685	98	14%
Rajshahi Area	77	(18:15-03:45)	670	96	14%
Comilla Area	47	(18:15-03:45)	462	65	14%
Mymensing Area	41	(18:15-03:45)	388	55	14%
Sylhet Area	39	(18:15-03:45)	302	31	10%
Barisal Area	23	(18:15-03:45)	141	20	14%
Rangpur Area	39	(18:15-03:45)	396	56	14%
<b>Total</b>	<b>561</b>	<b>19:30</b>	<b>6014</b>	<b>727</b>	

Information of the Generating machines under shut down.

	Planned Shut- Down	Forced Shut- Down
	1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal #6(18/07/10) 2) Khulna-60 MW(24/1/12) 3) Shahjibazar #5 & 6(21/7/11) 4) WMPL #1(1/5/12) 5) WMPL #2(24/4/13) 6) Raojan #2 (31/07/13) 7) Raozan #1 (15/08/13) 8) Sikalbaha 60 MW (15/08/13)
		9) Ashuganj GT #1 & 2, ST(8/9/13) 10) B. Pukuria #1 (23/9/13) 11) Sikalbaha-150(21/9/13)

**Additional Information of Machines. lines. Interruption / Forced Load shed etc.**

Description	Forced load shaded / Interrupted Areas
<p>a) There was generation shortage in the evening peak hour yesterday.</p> <p>b) Maniknagar-Matuail 132 kV Ckt &amp; Maniknagar-Haripur 132 kV Ckt tripped at 10:24 showing dist.zone-1 and were switched on at 10:43.</p> <p>c) Hathazari-Feni 132 kV Ckt was shut down at 10:10 due to red hot maintenance at Hathazari end and was switched on at 10:37.</p> <p>d) Tongi 132/33 kV T3 transformer tripped at 14:16 showing O/C relay and was switched on at 14:20.</p> <p>e) Palashbari 132/33 kV T3 transformer was under shut down from 12:30 to 14:10 due to A/M.</p> <p>f) Natore 132/33 kV T1 transformer was shut down at 14:31 due to red hot maintenance at 33 kV end and was switched on at 18:43.</p> <p>g) Mymensing-Netrokona 132 kV Ckt-1 was shut down at 13:02 due to breaker problem at Mymensing end and was switched on at 19:42.</p> <p>h) Haripur-Matuail 132 kV Ckt was shut down at 22:59 due to red hot maintenance of R-phase loop at Haripur end and was switched on at 00:57(26/9/13)</p> <p>i) Siddirganj P/S- Siddirganj S/S 132 kV Ckt was shut down at 05:59(26/9/13) due to project work.</p> <p>j) Naogaon-Bogra 132 kV Ckt-2 was shut down at 08:02(26/9/13) due to red hot maintenance of line isolator at Naogaon end.</p> <p>k) Noapara 33 kV Bus was shut down at 07:50(26/9/13) due to Narril 33 kV Bus isolator red hot.</p>	<p>So about 561 MW (19:30) of load shed was imposed over the whole areas of the national grid .</p> <p>Power interruption occurred (about 10 MW) under Matuail S/S areas from 22:59 to 00:57(26/9/13).</p>
<p>Deputy / Asstt. Manager Network Operation Division</p>	<p>Manager Network Operation Division</p>
	<p>Deputy General Manager Load Despatch Circle</p>