POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

			1000		LOAD DE	-	н	-	SITETD.		QF-LDC-08 Page -1
Till now the maximum generation is : -			6675 MWV	at		21:00			porting Date : 12-Jul-13	3-Nov-13	
The Summary of Yesterday's (2-Nov-13) Generation							obable Gen. & De	mand
Day Peak Generation :		4262.0	MW		Hour :	12:00		Min. Gen. at	5:00	3527	MW
Evening Peak Generation :		5851.0	MW		Hour :	19:30		Max Generatio	n :	6030	MW
E.P. Demand (at gen end) :		5851.0	MW		Hour :	19:30		Max Demand	:	6000	MW
Maximum Generation :		5851.0	MW		Hour :	19:30		Shortage	:	-30	MW
Total Gen. (MKWH) :		102.16	System L/ Factor	or :		81.11%	6	Load Shed	:	0	MW
		EXPO	RT/IMPORT THR	OUGH EAST-W	EST INTERCO	ONNECTOR	ł	•			
Export from East grid to West grid :- Maximu	m			250		MW	at	9:00	Energy	2.973	MKWHR.
Import from West grid to East grid :- Maximu	m			-		MW	at	-	Energy	-	MKWHR.
Wat	er Lev	el of Kaptai La	ke at 6:00 A M o	n		3-Nov-1	3				
Actual : 98.71 Ft.(MSL),				Rule curve :	108.80)	Ft.(MSL)			
Gas Consumed : Total		773.93	MMCFD.			Oil Consu	ıme	d (PDB):			
								. ,	HSD :		Liter
									FO :		Liter
Cost of the Consumed Fuel (PDB+Pvt) :	Gas	:		Tk61,801,398							
	240	Coal :		Tk16,098,971		Oil	:	Tk238,806,818	B Total :	Tk316,707,187	

Load Shedding & Other Information

Area	Yesterday		Today					
			Estimated Demand(s/s end)	Estimated Shedding (s/s end	Rates of Shedding			
	MW		from to/IW	MW	(On Estimated Demand)			
Dhaka	-	0:00	2237	-	-			
Chittagong Area	-	0:00	570	-	-			
Khulna Area	-	0:00	622	-	-			
Rajshahi Area	-	0:00	606	-	-			
Comilla Area	-	0:00	418	-	-			
Mymensing Area	-	0:00	348	-	-			
Sylhet Area	-	0:00	284	-	-			
Barisal Area	-	0:00	126	-	-			
Rangpur Area	-	0:00	356	-	-			
Total	0		5567	0				

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down	
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal #6(18/07/10) 2) Khulna-60 MW(24/1/12) 3) Shahjibazar #5 & 6(2(17/11)	9) Sikalbaha-150(21/9/13) 10) Siddirganj ST (03/10/13) 11) Ghorasal #2 (02/10/13) 12) Morecekt CT + NM/(48/40/42)
	4) WMPL #1(1/5/12) 5) WMPL #2(24/4/13) 6) Raojan #2 (31/07/13)	12) Megnaghat GT-1 MW (18/10/13) 13) Chandpur CCPP (02/11/13)
	7) Raozan #1 (15/08/13) 8) Ashuganj ST(8/9/13)	

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas		
a) Chandpur 150 MW CCPP was shut down at 08:05 (due to air filter change		
b) Kishoreganj 132/33 kV T1 transformer was shut down at 00.03 k	0		
c) Savar 132/33 kV T1 transformer was shut down fro			
d) Khulshi-Madughat 132 kV Ckt-1 was shut down from			
e) Faridpur-Madaripur 132 kV Ckt-1 was shut down fro			
f) Mongla 132/33 kV T1 transformer was shut down fro			
· · · · · · · · · · · · · · · · · · ·			
g) Comilla (N) 230/132 kV T01 transformer was shut d h) Aminbazar 230/132 kV T01 transformer was shut d			
i) Mymensingh 132/33 kV T1 transformer was shut dou			
j) Rampura-Ghorashal 230 kV Ckt-1 was shut down fr			
k) Ishurdi 132 kV bus-1 was shut down from 08:25 to 1			
I) Manikganj-Kabirpur 132 kV Ckt-1 was shut down fro			
m) Khulna (S) 230/132 kV T01 transformer was shut d			
n) Tangail 132/33 kV T2 transformer was shut down fr			
o) Hasnabad-Shampur 132 kV Ckt was shut down from			
p) Goalpara 33 kV bus was shut down from 07:44 to 1			
q) Jessore 132/33 kV T1 transformer was shut down fi			
r) Sreemongal 132/33 kV T1 transformer was shut dow			
s) Haripur 230/132 kV T01 transformer was shut dowr			
t) Bagherhat-Mongla 132 kV Ckt tripped at 10:16 show	ving distance A, B, C relay at Bagherhat end		
and was switched at 10:29.			
u) Sonargaon 132/33 kV T1 transformer was shut dow			
 v) Shyampur 132/33 kV GT-3 & 4 transformer was shu hot maintenance work. 	It down from 11:16 to 13:14 due to red		
 w) Comilla (S) 33 kV bus (partial) was shut down from maintenance work. 	09:35 to 10:32 due to red hot	About 10 MW power interruption occurred under Comilla (S) S/S areas from 09:35 to 10:32.	
x) Chandpur 132/33 kV T1 transformer was shut down	at 11:45 due to transformer change work.		
y) Hathazari-Comilla (N) 230 kV Ckt-2 tripped at 19:01	showing E/F, O/C (R-phase) relay at		
Hathazari end & primary distance protection, E/F pr	otection, secondary distance protection,		
voltage failure at Comilla (N) end and was switched	at 19:40.		
z) After maintenance Sylhet 150 MW was synchronize	d at 12:41.		
a) Chandpur-Chowmohani 132 kV Ckt-1 tripped at 05:			
at Chandpur end and was switched at 05:48 (03/11)			
b) Kaptai-Hathazari 132 kV Ckt-1 was shut down at 07			
c) Savar 132/33 kV T1 transformer was shut down at (
Deputy / Asstt. Manager	Manager	Deputy General Manager	
Network Operation Division	Network Operation Division	Load Despatch Circle	