POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

QF-LDC-08 QF-LDC-12

| | | DA | ILI REPORT | | | | Page -1 |
|---|-------------------|-----------------------------|-------------------|------------------|-----------------|--------------|---------|
| | | | - | | orting Date : | 8-Nov-13 | |
| Till now the maximum generation is : - | | 6675 MWW at | 21:00 | Hrs on | 12-Jul-13 | | |
| The Summary of Yesterday's (| 7-Nov-13 |) Generation & Demand | | Today's Actual M | /lin Gen. & Pro | bable Gen. & | Demand |
| Day Peak Generation : | 4544.0 | MW | Hour : 12:00 | Min. Gen. at | 5:00 | 3353 | MW |
| Evening Peak Generation : | 5933.0 | MW | Hour : 18:30 | Max Generation | . : | 5970 | MW |
| E.P. Demand (at gen end) : | 5933.0 | MW | Hour : 18:30 | Max Demand | : | 5900 | MW |
| Maximum Generation : | 5933.0 | MW | Hour : 18:30 | Shortage | : | -70 | MW |
| Total Gen. (MKWH) : | 104.20 | System L/ Factor : | 81.11% | Load Shed | : | 0 | MW |
| | EXP | ORT/IMPORT THROUGH EAST-WES | T INTERCONNECTOR | | | | |
| Export from East grid to West grid :- Maximum | | 260 | MW at | 8:00 | Energy | 3.089 | MKWHR. |
| Import from West grid to East grid :- Maximum | | | MW at | - | Energy | | MKWHR. |
| Water L | evel of Kaptai La | ake at 6:00 A M on | 8-Nov-13 | | | | |
| Actual : 98.24 Ft.(MSI | _) , | Ru | le curve : 108.30 | Ft.(MSL) | | | |
| Gas Consumed : Total | 757.37 | MMCFD. | Oil Consum | ed (PDB): | | | |
| | | | | () . | HSD : | | Liter |
| | | | | | FO : | | Liter |
| | | | | | | | |
| Cost of the Consumed Fuel (PDB+Pvt) : Ga | as : | Tk60,479,016 | | | | | |
| · · · · · | Coal : | Tk16,098,967 | Oil | : Tk231,402,446 | Total : T | k307,980,430 | C |

Load Shedding & Other Information

| Area | Yesterday | | | Today | | | |
|-----------------|-----------|------|---------------------------|---------------------------|--|--|--|
| | | | Estimated Demand(s/s end) | Estimated Shedding (s/s e | Estimated Shedding (s/s en Rates of Shedding | | |
| | MW | | from to/IW | MW | (On Estimated Demand) | | |
| Dhaka | - | 0:00 | 2225 | - | - | | |
| Chittagong Area | - | 0:00 | 568 | - | - | | |
| Khulna Area | - | 0:00 | 619 | - | - | | |
| Rajshahi Area | - | 0:00 | 603 | - | - | | |
| Comilla Area | - | 0:00 | 416 | - | - | | |
| Mymensing Area | - | 0:00 | 347 | - | - | | |
| Sylhet Area | - | 0:00 | 282 | - | - | | |
| Barisal Area | - | 0:00 | 126 | - | - | | |
| Rangpur Area | - | 0:00 | 355 | - | - | | |
| Total | 0 | | 5541 | 0 | | | |

Information of the Generating machines under shut down.

| Planned Shut- Down | Forced Shut- Down | | |
|--------------------------------|--------------------------------|---|--|
| 1) Haripur SBU GT-3 (18/06/09) | 1) Ghorasal #6(18/07/10) | 9) Sikalbaha-150(21/9/13) 17) Ashuganj-4(7/11 | |
| | 2) Khulna-60 MW(24/1/12) | 10) Siddirganj ST (03/10/13) | |
| | 3) Shahjibazar #5 & 6(21/7/11) | 11) Ghorasal #2 (02/10/13) | |
| | 4) WMPL #1(1/5/12) | #2(24/4/13) 13) Chandpur 163MW (06/11/13) | |
| | 5) WMPL #2(24/4/13) | | |
| | 6) Raojan #2 (31/07/13) | | |
| | 7) Raozan #1 (15/08/13) | 15) Ashuganj #1 (04/11/13) | |
| | 8) Ashuganj ST(CC)(8/9/13) | 16) Khulna 110 MW (05/11/13) | |

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

| Description | | Forced load shaded / Interrupted Areas |
|--|--|--|
| | | |
| a) Sylhet 132/33 kV T2 transformer was under maintenance. | shut down from 07:50 to 14:21 due to annual | |
| b) Aminbazar 230/132 kV T2 transformer was u annual maintenance | inder shut down from 08:08 from 16:13 due to | |
| c) Kishorganj 132/33 kV T2 transformer was un annual maintenance. | der shut down from 08:08 to 14:06 due to | |
| d) Rajshahi S/S-Rajshahi RPP 132 kV Ckt was maintenance. | shut down from 08:18 to 16:5 due to annual | |
| e) Chandpur-Comilla (S) 132 Ckt tripped at 09:0 at 10:10. | 05 showing dist.relay and was switched on | |
| Chandpur S/S-Chandpur 150 MW 132 kV Cl switched on at 10:53. | tt tripped at 09:05 showing diff.relay and was . | |
| g) Purbasadipur 132/33 kV T3 transformer was annual maintenance. | under shut down from 09:46 to 16:58 due to | |
| h) Shahjibazar 86 MW tripped at 13:02 showing | E/F relay and was switched on at 15:34. | |
|) After maintenance Ashuganj Unit-4 synchroni | zed at 17:15. | |
|) Ashuganj Unit-4 tripped at 21:15 due to DC s | upply fail and was switched on at 01:35 (08/11/13) | |
| k) Kabirpur 132/33 kV T2 transformer was shut now under maintenance. | down at 21:45 due to replacement work and is | |
|) Khulna(S)-Satkhira 132 kV Ckt tripped at 00: switched on at 01:10 (08/11/13). | 52 (08/11/13) showing dist. relay and was | |
| m) Ashuganj Unit-4 tripped at 01:35(08/11/13) o | due to HP bypass problem. | |
| | n at 07:45 (08/11/13) due to annual maintenance. | |
| Darity (Arath Managar | | Dearth Constra Manager |

Deputy / Asstt. Manager Network Operation Division

Manager Network Operation Division Deputy General Manager Load Despatch Circle