

POWER GRID COMPANY OF BANGLADESH LTD.
NATIONAL LOAD DESPATCH CENTER
DAILY REPORT

QF-LDC-08
Page -1

Till now the maximum generation is :-				6675 MW at		21:00		Hrs		Reporting Date : 11-Nov-13 on 12-Jul-13	
The Summary of Yesterday's (10-Nov-13) Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	4335.0	MW	Hour :	12:00	Min. Gen. at	5:00	3197	MW			
Evening Peak Generation :	5703.0	MW	Hour :	18:30	Max Generation :		5930	MW			
E.P. Demand (at gen end) :	5703.0	MW	Hour :	18:30	Max Demand :		5800	MW			
Maximum Generation :	5703.0	MW	Hour :	18:30	Shortage :		-130	MW			
Total Gen. (MKWH) :	99.98	System L/ Factor :		81.11%	Load Shed :		0	MW			
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum				270	MW	at	8:00	Energy	3.850	MKWHR.	
Import from West grid to East grid :- Maximum				-	MW	at	-	Energy	-	MKWHR.	
Water Level of Kaptai Lake at 6:00 A M on				11-Nov-13							
Actual :	97.87	Ft.(MSL) ,			Rule curve :	108.00	Ft.(MSL)				
Gas Consumed : Total		763.21	MMCFD.			Oil Consumed (PDB) :					
									HSD :	Liter	
									FO :	Liter	
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :	Tk60,945,364								
		Coal :	Tk15,770,417			Oil :	Tk164,828,202	Total :	Tk241,543,982		

Load Shedding & Other Information

Area	Yesterday		Today		
	MW		Estimated Demand(s/s end) from 10:00	Estimated Shedding (s/s end) MW	Rates of Shedding (On Estimated Demand)
Dhaka	-	0:00	2161	-	-
Chittagong Area	-	0:00	549	-	-
Khulna Area	-	0:00	598	-	-
Rajshahi Area	-	0:00	584	-	-
Comilla Area	-	0:00	404	-	-
Mymensing Area	-	0:00	337	-	-
Sylhet Area	-	0:00	275	-	-
Barisal Area	-	0:00	122	-	-
Rangpur Area	-	0:00	345	-	-
Total	0		5375	0	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal #6(18/07/10) 9) Sikalaha-150(21/9/13)
	2) Khulna-60 MW(24/1/12) 10) Siddirganj ST (03/10/13)
	3) Shahjibazar #5 & 6(21/7/11) 11) Ghorasal #2 (02/10/13)
	4) WMPL #1(1/5/12) 12) Megnaghat GT-1 MW (18/10/13)
	5) WMPL #2(24/4/13) 13) Chandpur 163MW (06/11/13)
	6) Raojan #2 (31/07/13) 14) Fenchuganj old ST (01/11/13)
	7) Raozan #1 (15/08/13) 15) Ashuganj #2 (04/11/13)
	8) Ashuganj ST(CC)(8/9/13) 16) Khulna 110 MW (05/11/13)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
<p>a) Mymensingh132/33 kV T3 transformer was under shut down from 08:31 to 13:10 due to maintenance work.</p> <p>b) Thakurgaon 132/33 kV T1 transformer was under shut down from 08:15 to 14:52 due to annual maintenance work.</p> <p>c) Aminbazer 132/33 kV T1 transformer was under shut down from 09:02 to 17:22 due to annual maintenance work.</p> <p>d) Saver 132/33 kV T2 transformer was under shut down from 08:21 to 16:46 due to annual maintenance work.</p> <p>e) Bagerhat 132/33 kV T2 transformer was under shut down from 09:08 to 13:52 due to annual maintenance work.</p> <p>f) Lalmonirhat 132/33 kV T1 transformer was under shut down from 09:20 to 12:40 due to annual maintenance work.</p> <p>g) Tangail 132/33 kV T1 transformer was under shut down from 09:30 to due to 11:40 annual maintenance work.</p> <p>h) Fenchuganj 132/33 kV T2 transformer was under shut down from 09:13 to due to 12:58 annual maintenance work.</p> <p>i) Jhenidah-Jessore 132 kV Ckt-1 was under shut down from 08:21 to 16:46 due to annual maintenance work.</p> <p>j) Kabirpur-Manikganj 132 kV Ckt-2 was under shut down from 09:08 to 13:52 due to annual maintenance work.</p> <p>k) Rampura 230/132 kV T1 transformer is under shut down since 07:53(11/11/13) due to annual maintenance work.</p>	
Deputy / Asstt. Manager Network Operation Division	Deputy General Manager Load Despatch Circle

Manager
Network Operation Division