

**POWER GRID COMPANY OF BANGLADESH LTD.**  
**NATIONAL LOAD DESPATCH CENTER**  
**DAILY REPORT**

QF-LDC-08 QF-LDC-12  
Page -1

Till now the maximum generation is :-			6675 MW at		21:00		Hrs		Reporting Date : 24-Nov-13		
The Summary of Yesterday's (			23-Nov-13		) Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand				
Day Peak Generation :			3948.0		MW		Hour :		12:00		
Evening Peak Generation :			5643.0		MW		Hour :		18:30		
E.P. Demand (at gen end) :			5643.0		MW		Hour :		18:30		
Maximum Generation :			5643.0		MW		Hour :		18:30		
Total Gen. (MKWH) :			93.53		System L/ Factor :		81.11%		Load Shed		
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum			380		MW		at		21:00		
Import from West grid to East grid :- Maximum			-		MW		at		-		
Water Level of Kaptai Lake at 6:00 A M on 24-Nov-13											
Actual :			96.22		Ft.(MSL) ,		Rule curve :		106.70		
Gas Consumed : Total			724.88		MMCFD.		Oil Consumed (PDB) :				

**Load Shedding & Other Information**

Area	Yesterday		Today		
	MW		Estimated Demand(s/s end) from 10:00	Estimated Shedding (s/s end) MW	Rates of Shedding (On Estimated Demand)
Dhaka	-	0:00	2199	-	-
Chittagong Area	-	0:00	560	-	-
Khulna Area	-	0:00	610	-	-
Rajshahi Area	-	0:00	595	-	-
Comilla Area	-	0:00	411	-	-
Mymensing Area	-	0:00	343	-	-
Sylhet Area	-	0:00	279	-	-
Barisal Area	-	0:00	124	-	-
Rangpur Area	-	0:00	351	-	-
<b>Total</b>	<b>0</b>		<b>5472</b>	<b>0</b>	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal #6(18/07/10) 9) Sikalbaha-150(21/9/13) 17) Ghorasal #5 (23/11/13)
	2) Khulna-60 MW(24/1/12) 10) Ghorasal #2 (02/10/13)
	3) Shahjibazar #5 & 6(21/7/11) 11) Barapukuria #1(20/11/13)
	4) WMPL #1(1/5/12) 12) Fenchuganj old ST (01/11/13)
	5) WMPL #2(24/4/13) 13) Khulna 110 MW (05/11/13)
	6) Raojan #2 (31/07/13) 14) Ghorasal-3(16/11/13)
	7) Raozan #1 (15/08/13) 15) Chandpur-163MW(14/11/13)
	8) Ashuganj ST(CC)(8/9/13) 16) Fenchugang GT4(17/11/13)

**Additional Information of Machines. lines. Interruption / Forced Load shed etc.**

Description	Forced load shaded / Interrupted Areas
<p>a) Sylhet-Chatak 132 kV Ckt-1 was shut down from 08:14 to 15:03 due to A/M.</p> <p>b) Haripur-Madanganj 132 kV Ckt was shut down from 08:16 to 10:18 due to protection test.</p> <p>c) Khulna Central 132/33 kV T1 transformer was shut down from 08:29 to 13:57 due to A/M.</p> <p>d) Aminbazar-Savar 132 kV Ckt-1 was shut down from 08:36 to 17:34 due to A/M.</p> <p>e) Feni-Hathazari 132 kV Ckt-2 was shut down from 08:45 to 14:51 due to A/M.</p> <p>f) Rampura-Mogbazar 132 kV Ckt-2 was shut down from 09:06 to 17:18 due to A/M.</p> <p>g) Noapara 132/33 kV T2 transformer was shut down from 09:13 to 16:05 due to A/M.</p> <p>h) Ullon-Siddhirganj 132 kV Ckt-1 was shut down from 09:28 to 16:45 due to A/M.</p> <p>i) Jessore 33 kV bus was shut down from 09:27 to 14:37 due to A/M.</p> <p>j) Haripur 230/132 kV T3 transformer was shut down from 09:35 to 16:50 due to A/M.</p> <p>k) B. Baria-Shahjibazar 132 kV Ckt-1 was shut down from 09:46 to 15:20 due to A/M.</p> <p>l) Narsingdi 132/33 kV T1 transformer was shut down from 08:04 to 16:40 due to A/M.</p> <p>m) Kishoreganj-Ashuganj 132 kV Ckt-1 was shut down from 08:20 to 15:42 due to A/M.</p> <p>n) Modunaghat-Sikalbaha 132 kV Ckt-1 was shut down from 08:32 to 17:10 due to A/M.</p> <p>o) Bogra-Palashbari 132 kV Ckt-1 was shut down from 08:20 to 16:21 due to A/M.</p> <p>p) Haripur-Shaympur 132 kV Ckt was shut down from 10:24 to 11:53 due to A/M.</p> <p>q) Haripur-Matuail 132 kV Ckt was shut down from 13:24 to 14:45 due to protection test.</p> <p>r) Sylhet S/S-Sylhet 20 MW P/S Ckt was shut down from 10:45 to 16:51 due to A/M.</p> <p>s) Hasnabad 132 kV reserve bus was shut down from 14:48 to 16:10 due to A/M.</p> <p>t) Purbasadiipur 132/33 kV T1 transformer was shut down at 14:25 due to replacing by new 132/33 kV 50/75 MVA transformer.</p> <p>u) Munshiganj 132/33 kV T2 transformer was shut down at 20:15 due to energy meter burnt.</p> <p>v) Baghabari 71 MW was shut down at 07:10(24/11/13) due to filter change.</p> <p>w) Patuakhali 132/33 kV T1 transformer was shut down at 06:56(24/11/13) due to A/M.</p>	<p>About 48 MW power interruption occurred under Jessore S/S areas from 09:27 to 14:37.</p> <p>About 20 MW power interruption occurred under Narsingdi S/S areas from 08:04 to 16:40.</p> <p>About 20 MW power interruption occurred under Matuail S/S areas from 13:24 to 14:45.</p>
Deputy / Asstt. Manager Network Operation Division	Manager Network Operation Division
	Deputy General Manager Load Despatch Circle