POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER. LDC.DHAKA DAILY REPORT

				Reporting Date :	22-Jun-10	
Till now the maximum generation is :	:-	4606.0 MW at	22:00	Hrs on 14-Apr-10		
The Summary of Yesterday's (21-Jun-10) Generation & Demand		Today's Actual Min Gen. & F	robable Gen. & Demand	
Day Peak Generation :	3600.0	MW Hour :	10:00	Min Gen. at 7:00	3673 MW	
Evening Peak Generation :	3678.5	MW Hour :	20:00	Max Generation :	3731 MW	
E.P. Demand (at gen end) :	5000.0	MW Hour :	20:00	Max Demand :	5000 MW	
Maximum Generation :	3909.0	MW Hour :	4:00	Shortage :	1269 MW	
Total Gen. (MKWH) :	86.63	System L/ Factor :	85.41%	Load Shed :	1074 MW	
	EXPOR	T/IMPORT THROUGH EAST	-WEST INTERCONNECTOR			
Export from East grid to West grid :- M	aximum	440	MW at	5:00 Energy	7624000 KWHR.	
Import from West grid to East grid :- M	aximum	-	MW at	- Energy	- KWHR.	
	Water Level of Kaptai Lak	e at 6:00 A M of	22-Jun-10			
Actual : 92.41	Ft.(MSL),		Rule curve : 81.57	Ft.(MSL)		
Gas Consumed : Total	735.23	MMCFt.	Oil Consume	· · ·		
				HSD :	134687 Liter	
				FO :	0 Liter	

Cost of the Consumed Fuel (PDB): Gas :

Tk54,340,849

Oil : Tk5,387,473 Total : Tk59,728,322

Load Shedding & Other Information

Area	Yesterday			Today	
			Estimated Demand(s/s end)	Estimated Shedding (s/s e	Rates of Shedding
	MW		from to/W	MW	(On Estimated Demand)
Dhaka	420	(18:30 - till now, gen. shortage)	1845	459	25%
Chittagong Area	153	(18:30 - till now, gen. shortage)	528	144	27%
Khulna Area	153	(18:30 - till now, gen. shortage)	468	132	28%
Rajshahi Area	131	(18:30 - till now, gen. shortage)	388	109	28%
Comilla Area	101	(18:30 - till now, gen. shortage)	302	83	27%
Mymensing Area	70	(18:30 - 06:08, gen. shortage)	225	62	28%
Sylhet Area	-	0	174	-	-
Barisal Area	22	(18:30 - till now, gen. shortage)	93	26	28%
Rangpur Area	69	(18:30 - till now, gen. shortage)	209	59	28%
Total	1119	20:00	4232	1074	

Information of the Generating machines under shut down.

.....

Planned Shut- Down	Forced Shut- Down		
	1) Kaptai- 3 (19/04/08)	8) Siddhirganj GT-1 (16/06/10)	
	2) Khulna 110MW (31/03/09)	9) Siddhirganj GT-2 (06/06/10)	
	3) Haripur SBU GT-3 (18/06/09)		
	4) Ashuganj CCPP ST (05/12/09)		
	5) Raozan -1 (08/05/10)		
	6) Ghorasal 2(26/04/10)		
	7) Kaptai- 4 (17/01/10)		

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description		Forced load shaded / Interrupted Areas
a) There was generation shortage in the eve	ening peak hour yesterday.	So about 1119 MW (20:00) of load shed was imposed over the
		whole (except Sylhet) areas of the national grid.
b) Due to gas limitation, Raozan (180 MW),	RPCL (210 MW), NEPC (110 MW), HPL (360 MW)	
and MPL (450 MW) were limited to 100 M	/W,74 MW, 18 MW, 298 MW and 360 MW respectively.	
c) Baghabari GT-1 (71 MW) was synchroniz gas pressure low.	zed at 09:30. But it was shut down at 20:42 due to	
d) Tongi GT was shut down at 10:28 due to	gas pressure low and was synchronized at 00:24 (22/06/10)).
e) After maintenance, Ashuganj unit -3 was due to problem of turbine and was synchi	synchronized at 18:24 but it was shut down at 19:22 ronized at 21:45.	
f) Rangpur 132/33 KV T2 transformer was u maintenance of 33 KV bus isolator.	under shut down from 12:40 to 12:55 due to red-hot	
g) Hasnabad 33 bus was under shut down f 33 KV bus isolator.		Power interruption (50 MW) occurred under Hasnabad S/S areas from 11:20 to 12:40.
' O/C, E/F', ' DIST prot' & ' DIST BC' resp 132 KV line and Madaripur - Barisal 132 l	tripped at 12:55 from Bheramara and both end showing ectively. At the same time Bhandaria - Bagerhat KV line also tripped from Bagerhat end and Madaripur respectively. The lines were switched on at 14:03,	Power interruption (85 MW) occurred under Barisal , Bhandaria, Madaripur and Gopalganj S/S areas from 12:55 to 13:05.
		Due to generation shortage, about 350 MW (09:00) of load shed has been running since morning (22/06/10) over the whole area (except Sylhet) of the national grid.
Deputy / Asstt. Manager	Manager	Deputy General Manager
Load Despatch Division	Load Despatch Division	Load Despatch Circle

QF-LDC-08 Page -1