

QF-LDC-08
Page -1

Reporting Date : 20-Mar-14

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Actual :		87.51	Ft.(MSL) ,		Rule curve :		89.96	Ft.(MSL)	
----------	--	-------	------------	--	--------------	--	-------	------------	--

Cost of the Consumed Fuel (PDB+Pvt) :	Gas :	Tk71,201,651			
	Coal :	Tk16,483,967	Oil :	Tk342,340,583	Total : Tk430,026,201

Area	Yesterday		Today		
			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding
	MW		from to MW	MW	(On Estimated Demand)
Dhaka	-	0:00	2492	-	-
Chittagong Area	-	0:00	642	-	-
Khulna Area	-	0:00	702	-	-
Rajshahi Area	-	0:00	680	-	-
Comilla Area	-	0:00	467	-	-
Mymensingh Area	-	0:00	385	-	-
Sylhet Area	-	0:00	313	-	-
Barisal Area	-	0:00	139	-	-
Rangpur Area	-	0:00	393	-	-
Total	0		6213	0	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal #6 (18/07/10) 2) Khulna-60MW (24/1/12) 3) Shahjibazar #5 & 6 (21/7/11) 4) WMPL #1(1/5/12) 5) WMPL #2(24/4/13) 6) Raojan #2(31/07/13) 7) Ashugonj ST-1(16/03/14) 8) Ashugonj #1(CCPP) (06/01/14) 7) Ashugonj ST-2(12/03/14)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) After maintenance Megnaghat GT #1 was synchronized at 09:46.	About 56 MW power interruption occurred under Bakulia S/S areas from 10:20 to 11:55.
b) Bakulia 132/33 kV T-1 & T-2 transformers were tripped at 09:20 showing O/C relay at 132kV end and were switched on at 11:25,11:55 respectively.	
c) Maniknagar 132 kV bus coupler shut down at 11:55 due to project work.	
d) Raozan ST-1 tripped 12:13 due to burner problem and was synchronized at 12:46.	
e) Uttara-Tongi 132 kV Ckt shut down from 13:02 to 15:07 due to red hot maintenance work at Uttara end.	
f) Hasnabad 132/33 kV T5 transformer was shut down from 10:40 to 15:26 due to project work.	
g) Raozan-Hathazari 230 kV Ckt-1 tripped at 12:13 from both end showing distance Z1 relay and was switched on at 12:46.	
h) After maintenance Sikalbaha GT 150 MW was synchronized at 13:50.	
i) Haripur-Shaympur 132 kV Ckt tripped at 13:48 from both end showing dist Z1, CN relay at Haripur end and distance Z1 at Shaympur end and was switched on at 13:52.	
j) Ishurdi 230/132 kV T01 transformer tripped at 19:22 showing primary protection relay burst Y phase CVT 132 kV end .	About 7 MW power interruption occurred under Tongi S/S areas from 01:15(20/03/2014). to 01:40(20/03/2014).
k) Tongi 132/33 kV T1 & T3 transformers were tripped at 01:15(20/03/2014) showing E/F & over current relay and were switched on at 01:40(20/03/2014).	
l) Sylhet 150 MW was shut down at 00:03(20/03/2014) due to differential pressure high.	

Deputy General Manager
Load Despatch Circle