

Till now the maximum generation is :-				7356 MW		20:00		Hrs on 30-Mar-14		Reporting Date : 1-May-14	
The Summary of Yesterday's (30-Apr-14				Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :		5829.0		MW		Hour :		12:00		Min. Gen. at 8:00 5138 MW	
Evening Peak Generation :		6906.0		MW		Hour :		20:00		Max Generation : 7027 MW	
E.P. Demand (at gen end) :		7100.0		MW		Hour :		20:00		Max Demand : 7000 MW	
Maximum Generation :		6906.0		MW		Hour :		20:00		Shortage : -27 MW	
Total Gen. (MKWH) :		132.9		System L/ Factor :		78.37%		Load Shed :		0 MW	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum				-100		MW at 15:00		Energy 7.867		MKWHR.	
Import from West grid to East grid :- Maximum				-		MW at -		Energy -		MKWHR.	
Water Level of Kaptai Lake at 6:00 A M on 1-May-14											
Actual :		87.64		Ft.(MSL) ,		Rule curve :		82.00		Ft.(MSL)	
Gas Consumed : Total		950.93		MMCFD.		Oil Consumed (PDB) :		HSD : Liter		FO : Liter	
Cost of the Consumed Fuel (PDB+Pvt) :				Gas : Tk80,563,610		Oil : Tk375,064,686		Total : Tk471,487,277			
				Coal : Tk15,858,981							
Load Shedding & Other Information											
Area	Yesterday			Estimated Demand(s/s end)				Today			
	MW			MW				Estimated Shedding (s/s end) MW Rates of Shedding (On Estimated Demand)			
Dhaka	-	0:00		2456			-			-	
Chittagong Area	28	(18:45-21:05)		632			-			-	
Khulna Area	30	(18:45-21:05)		691			-			-	
Rajshahi Area	27	(18:45-21:05)		670			-			-	
Comilla Area	25	(18:45-21:05)		461			-			-	
Mymensingh Area	26	(18:45-21:05)		380			-			-	
Sylhet Area	-	0:00		309			-			-	
Barisal Area	10	(18:45-21:05)		137			-			-	
Rangpur Area	29	(18:45-21:05)		388			-			-	
	-										
Total	175			6124			0				
Information of the Generating machines under shut down.											
	Planned Shut- Down						Forced Shut- Down				
	1) Haripur SBU GT-3 (18/06/09)						1) Ghorasal #6 (18/07/10)		9) Fenchuganj CCPP old #1 (30/04/2014)		
							2) Khulna-60MW (24/1/12)		10) Haripur EGCB 412MW ST(01/05/14)		
							3) Shahjibazar #5 & 6 (21/7/11)				
							4) WMPL #1(1/5/12)				
							5) WMPL #2(2/4/13)				
							6) Ashuganj GT-1(CCPP) (06/01/14)				
							7) Meghnaghat 450MW(21/04/2014)				
							8) Khulna 110 MW (29/04/2014)				
Additional Information of Machines. lines. Interruption / Forced Load shed etc.											
Description							Forced load shaded / Interrupted Areas				
a) After maintenance Joydevpur-Kabirpur 132 kV Ckt-1 was switched on 08:33.											
b) Sikalbaha 132/33 kV T1 transformer tripped at 09:02 showing over current relay and was switched on 10:15.											
c) HVDC Bheramara-Baharampur 400 kV Ckt-2 was shut down from 11:00 to 13:41 due to sub-station works at Baharampur end.											
d) Madaripur 132/33 kV T3 transformer was shut down from 11:54 to 15:20 due to replacement work of auxiliary transformer.											
e) Haripur 360 MW ST was shut down at 14:00 due to inspection and was synchronized on 17:16.											
f) After maintenance Baghabari-Serajganj 230 kV Ckt-1 was switched on 15:12.											
g) Haripur-Maniknagor 132 kV Ckt-2 was shut down from 05:53 to 07:16(01/05/2014) due to project work.											
h) Baghabari 100 MW was shut down at 06:01(01/05/2014) die to oil pump maintenance work.											
i) Haripur EGCB 412 MW ST was shut down at 00:59(01/05/2014) due to maintenance work.											
j) Haripur-Siddhirganj 132 kV Ckt-1 was shut down from 07:47 to 09:48(01/05/2014) due to project work.											
Deputy / Asstt. Manager Network Operation Division							Manager Network Operation Division				
							Deputy General Manager Load Despatch Circle				