QF-LDC-08 Page -1

Reporting Date : 6-May-14 Till now the maximum generation
The Summary of Yesterday's (
Day Peak Generation : 7356 MW Generation & Demand MW Hrs on 30-Mar-14
Today's Actual Min Gen. & Probable Gen. & Demand 5-May-14 5518.0 12:00 Hour Evening Peak Generation E.P. Demand (at gen end) Maximum Generation 6689.0 MW Hour 21:00 Max Generation 6865 MW 6689.0 6689.0 Hour : 21:00 21:00 21:00 7000 135 MW Max Demand MW MW Shortage Total Gen. (MKWH) 134.1 78.37% Load Shed 124 MW Export from East grid to West grid :- Maximum MKWHR. Energy 7.867 Import from West grid to East grid :- Maximum at Energy MKWHR Water Level of Kaptai Lake at 6:00 A M on 6-May-14 81.05 Ft.(MSL) Ft.( MSL ) Actual: Rule curve Gas Consumed : Total 935.96 MMCFD Oil Consumed (PDB): HSD FO Cost of the Consumed Fuel (PDB+Pvt) : Tk77,412,088 : Tk426,993,083 Total : Tk518,975,122 Tk14,569,951 Load Shedding & Other Information Today Estimated Shedding (s/s end) Area Yesterday Rates of Shedding Estimated Demand(s/s end) MW (On Estimated Demand) Dhaka Chittagong Area 0:00 675 Khulna Area 0:00 739 25 715 491 0:00 24 Rajshahi Area Comilla Area 0:00 16 403 13 Mymensingh Area 0:00 Svlhet Area 0.00 328 10 Barisal Area 141 0:00 Rangpur Area 0:00 412 13 6433 124 Information of the Generating machines under shut down. Planned Shut- Down
1) Haripur SBU GT-3 (18/06/09) Forced Shut-Down 9) Fenchuganj CCPP old #1 (30/04/2014) 1) Ghorasal #6 (18/07/10) 2) Khulna-60MW (24/1/12) 10) Ashugani #1 (03/05/2014) 3) Shahjibazar #5 & 6 (21/7/11) 11) Ghorasal #1 (01/05/2014) 4) WMPL #1(1/5/12) 5) WMPL #2(24/4/13) 6) Ashuganj GT-1(CCPP) (06/01/14) 7) Meghnaghat 450MW(21/04/2014) 8) Khulna 110 MW (29/04/2014) Additional Information of Machines. lines. Interruption / Forced Load shed etc. Description Forced load shaded / Interrupted Areas a) Comilla(S) 132/33 kV T2 transformer was shut down at 09:22 due to red hot maintenance at 33 kV About 10 MW power interruption occurred under Comilla(S) S/S areas Bus isolator and was switched on at 09:52. from 09:22 to 09:52. b) Jangalia-33 MW was shut down at 08:27 due to red hot maintenance at isolator power plant end and was switched on at 09:15.
 c) Kishorganj 132/33 kV T1, T2 & T3 transformers were shut down at 08:13 due to red hot maintenance. About 19 MW power interruption occurred under Kishorganj S/S areas at Nandail feeder bus isolator and were switched on at 09:01 from 08:13 to 09:01. of Faridpur-Madaripur 132 kV Ckt-1 was shut down at 09:17 due to replacing isolator at Faridpur end and was switched on at 12:40. e) Raozan #1 tripped at 17:01 due to problem at 230 kV CB and was sync.at 02:51(6/5/14). f) Hathazari 132/33 kV T1 & T2 transformers tripped at 19:53 showing E/F relay and were switched on About 53 MW power interruption occurred under Hathazari S/S areas from 19:53 to 21:40. at 23:36 & 21:40 respectively.
g) Barapukuria #1 was shut down at 23:02 due to boiler tube leakage

Sub Divisional Engineer Network Operation Division

Executive Engineer Network Operation Division Superintendent Engineer Load Despatch Circle