

Till now the maximum generation is :-				7356 MW		20:00		Hrs on 30-Mar-14		Reporting Date : 7-May-14	
The Summary of Yesterday's (6-May-14				Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	5944.0	MW	Hour :	12:00	Min. Gen. at	6:00	4983	MW			
Evening Peak Generation :	6710.0	MW	Hour :	21:00	Max Generation :		6775	MW			
E.P. Demand (at gen end) :	6710.0	MW	Hour :	21:00	Max Demand :		7000	MW			
Maximum Generation :	6710.0	MW	Hour :	21:00	Shortage :		225	MW			
Total Gen. (MKWH) :	139.0	System L/ Factor :		78.37%	Load Shed :		206	MW			
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum				-30	MW	at	18:30	Energy	7.867	MKWHR.	
Import from West grid to East grid :- Maximum				-	MW	at	-	Energy	-	MKWHR.	
Actual : 87.64				Water Level of Kaptai Lake at 6:00 A M on 7-May-14				Ft.(MSL)			
				Rule curve :				80.86			
Gas Consumed : Total 957.63				MMCFD.				Oil Consumed (PDB) :			
								HSD : Liter			
								FO : Liter			
Cost of the Consumed Fuel (PDB+Pvt) : Gas : Tk82,723,948											
Coal : Tk8,241,979								Oil : Tk399,560,651 Total : Tk490,526,579			
Load Shedding & Other Information											
Area											
Yesterday											
Estimated Demand(s/s end)											
MW											
Dhaka - 0:00 2541											
Chittagong Area - 0:00 671											
Khulna Area - 0:00 734											
Rajshahi Area - 0:00 710											
Comilla Area - 0:00 489											
Mymensingh Area - 0:00 402											
Sylhet Area - 0:00 313											
Barisal Area - 0:00 139											
Rangpur Area - 0:00 411											
Total 0 6410											
Today											
Estimated Shedding (s/s end)											
MW											
54 -											
30 -											
33 -											
31 -											
22 -											
18 -											
18 -											
206											
Information of the Generating machines under shut down.											
Planned Shut- Down											
1) Haripur SBU GT-3 (18/06/09)											
Forced Shut- Down											
1) Ghorasal #6 (18/07/10)											
2) Khulna-60MW (24/1/12)											
3) Shahjibazar #5 & 6 (21/7/11)											
4) WMPL #1(1/5/12)											
5) WMPL #2(24/4/13)											
6) Ashuganj GT-1(CCPP) (06/01/14)											
7) Meghnaghat 450MW(21/04/2014)											
8) Fenchuganj CCPP old #1 (30/04/2014)											
9) Fenchuganj CCPP old #1 (30/04/2014)											
10) Khulna 150 MW (06/05/14)											
Additional Information of Machines. lines. Interruption / Forced Load shed etc.											
Description											
Forced load shaded / Interrupted Areas											
a) Haripur-Narshingdi 132 kV Ckt was under shut down from 09:32 to 18:32 due to new tower erection.											
b) Haripur-Bhulta 132 kV Ckt was under shut down from 09:33 to 18:20 due to new tower erection.											
c) Kishorganj 132/33 kV T3 transformer was under shut down from 10:44 to 11:19 due to 33 kV line maintenance.											
d) Narshingdi 132/33 kV T1 transformer was under shut down from 13:06 to 15:10 due to CT ratio change.											
About 10 MW power interruption occurred under Kishorganj (S) S/S areas from 10:44 to 11:19.											
About 38 MW power interruption occurred under Narshingdi S/S areas from 13:06 to 15:10.											